

BLOCK COMPLIANCE

Calculation Type: New Build (As Designed)

Block Reference	Block 13-16	Issued on Date	18/07/2023
Block Name			
Assessor Details	Mr. Paul Pasifull, Paul Pasifull, Tel: 07737 798 021, Paul@lpenergy.co.uk	Assessor ID	q133-0001
Client			

Block Compliance Report - DER

Block Reference: Block 13-16		Block Name:			
Property-Assessment Reference	Multiplier	Floor Area (m ²)	DER (kgCO ₂ /m ²)	TER (kgCO ₂ /m ²)	% DER/TER
Flat 13-Design	1	46.88	22.50	28.91	22.18 %
Flat 14-Flat 14	1	45.1	21.99	27.96	21.35 %
Flat 15-Flat 15	1	46.83	24.67	30.51	19.14 %
Flat 16-001	1	43.53	24.37	31.02	21.43 %
Totals:	4	182.34	93.53	118.39	
Average DER = 23.38 kgCO ₂ /m ²		% DER/TER	PASS		
Average TER = 29.59 kgCO ₂ /m ²		20.99 %			

Block Compliance Report - DFEE

Block Reference: Block 13-16		Block Name:			
Property-Assessment Reference	Multiplier	Floor Area (m ²)	DFEE (kWh/m ² /yr)	TFEE (kWh/m ² /yr)	% DFEE/TFEE
Flat 13-Design	1	46.88	38.98	45.31	13.98 %
Flat 14-Flat 14	1	45.1	35.95	40.03	10.21 %
Flat 15-Flat 15	1	46.83	42.13	51.63	18.40 %
Flat 16-001	1	43.53	41.42	50.20	17.48 %
Totals:	4	182.34	158.48	187.18	
Average DFEE = 39.62 kWh/m ² /yr		% DFEE/TFEE	PASS		
Average TFEE = 46.80 kWh/m ² /yr		15.34 %			