


Waste pipe sizes:-
Svp. stub stack: 110mm dia
W.C. & branches: 110mm dia. (fall 18-90mm/m)
Kitchen sink, basin & bath (<1.7mm run) 32mm dia. (fall 18-22mm/m)
Kitchen sink, basin & bath (1.7-3.0m run) 40mm dia. (fall 18-90mm/m)
Kitchen sink, basin & bath (3.0m-4.0m run) 50mm dia. (fall 18-90mm/m)

All drains formed in 110mm dia. PVCu pipework (BS 4660 & BS5481) laid to min. 1:60 fall bedded in pea shingle to BS 882:1983 Table 4 or BS 8301:1985 Appendix D. All joints to be flexible.

All underground drainage to generally comply with Building Regulations Approved Document H2.



	STEPHEN BIDDLE BSc CEng FICE Email: stephen@sbiddle.co.uk Mob: 07864 122 313 Web: www.sbiddle.co.uk	
	Title: PROPOSED FIRST FLOOR PLAN	Scale: 1:50 (A2)
Drwg No: CLARKE-0523-02	Rev: A	