

Brett, David

From: Kay Collins <kay@solveplanning.co.uk>
Sent: 24 November 2022 13:36
To: Brett, David
Subject: RE: Reading Link Retail Park - NMA Application
Attachments: 167 MODEL - A-1001D - PROPOSED ELEVATIONS 1.pdf; 167 MODEL - A-1002D - PROPOSED ELEVATIONS 2.pdf

This is an EXTERNAL EMAIL. STOP THINK before you CLICK links or OPEN attachments.

Good afternoon David

The attached drawings are the ones submitted to discharge condition 4 and which contains this detail.

The information you need is as follows:

Glazing – Aluminium Powder coated (Colour RAL 7021) shopfront frames fitted with double glazing
Door – 1150mm wide aluminium framed composite door, side panels and fanlight (RAL7021)
Cladding – Powder coated panels Black (RAL 9005)
Cladding (Feature Panel) – Accoya LT AC 02 Profiled Acetylated Vertical Boards
Fascias – Aluminium verge fascia finished Dark Grey (RAL 7016)
Guttering – Box section gutter powder coated dark grey (RAL 7016)

I hope this helps along with the detail on the attached plans.

Kind regards

Kay

Kay Collins
Associate Director

T: 01252 916655
M: 07826 069763
S/B: 01252 419978

My normal working week is Monday to Thursday



NEW ADDRESS:: Cheyenne House, West Street, Farnham, Surrey, GU9 7EQ
NEW TELEPHONE: 01252 916655

kay@solveplanning.co.uk www.solveplanning.co.uk

By following us on LinkedIn you will be able to follow our updates on key changes and developments in planning <https://www.linkedin.com/company/solve-planning-limited/>

The information contained in this email is privileged, confidential and protected from disclosure. If you are not the intended recipient of this or any part of it then please telephone us immediately on 01252 419978. You must not take copies or disclose the contents of this to anyone.