

BASIC COMPLIANCE REPORT

Calculation Type: New Build (As Designed)

Property Reference	Unit 1C Eldon Terrace	Issued on Date	12/07/2021
Assessment Reference	001	Prop Type Ref	SF Flat
Property			

SAP Rating	86 B	DER	14.24	TER	17.78
Environmental	90 B	% DER<TER	19.90		
CO ₂ Emissions (t/year)	0.85	DFEE	34.19	TFEE	42.55
General Requirements Compliance	Pass	% DFEE<TFEE	19.64		

Assessor Details	Mr. Andrew Sadler, Build Pass Ltd, Tel: 01962 657180, andrew@buildpass.co.uk	Assessor ID	P628-0001
Client			

SUMMARY FOR INPUT DATA FOR New Build (As Designed)

Criterion 1 – Achieving the TER and TFEE rate

1a TER and DER

Fuel for main heating	Mains gas		
Fuel factor	1.00 (mains gas)		
Target Carbon Dioxide Emission Rate (TER)	17.78	kgCO ₂ /m ²	
Dwelling Carbon Dioxide Emission Rate (DER)	14.24	kgCO ₂ /m ²	Pass
	-3.54 (-19.9%)	kgCO ₂ /m ²	

1b TFEE and DFEE

Target Fabric Energy Efficiency (TFEE)	42.55	kWh/m ² /yr	
Dwelling Fabric Energy Efficiency (DFEE)	34.19	kWh/m ² /yr	
	-8.3 (-19.5%)	kWh/m ² /yr	Pass

Criterion 2 – Limits on design flexibility

Limiting Fabric Standards

2 Fabric U-values

Element	Average	Highest	
External wall	0.18 (max. 0.30)	0.18 (max. 0.70)	Pass
Party wall	0.00 (max. 0.20)	-	Pass
Floor	0.12 (max. 0.25)	0.12 (max. 0.70)	Pass
Roof	0.13 (max. 0.20)	0.17 (max. 0.35)	Pass
Openings	1.11 (max. 2.00)	1.40 (max. 3.30)	Pass

2a Thermal bridging

Thermal bridging calculated from linear thermal transmittances for each junction

3 Air permeability

Air permeability at 50 pascals	4.00 (design value)	
Maximum	10.0	Pass

Limiting System Efficiencies

4 Heating efficiency

BASIC COMPLIANCE REPORT

Calculation Type: New Build (As Designed)

Main heating system

Boiler system with radiators or underfloor - Mains gas
Data from database
Worcester Greenstar 25Si Compact ErP
Combi boiler
Efficiency: 89.8% SEDBUK2009
Minimum: 88.0%

Pass

Secondary heating system

None

5 Cylinder insulation

Hot water storage

No cylinder

6 Controls

Space heating controls

Time and temperature zone control

Pass

Hot water controls

No cylinder

Boiler interlock

Yes

Pass

7 Low energy lights

Percentage of fixed lights with low-energy fittings

100 %

Minimum

75 %

Pass

8 Mechanical ventilation

Continuous extract system (decentralised)

Specific fan power

0.1600 0.1600

Maximum

0.7

Pass

Criterion 3 – Limiting the effects of heat gains in summer

9 Summertime temperature

Overheating risk (Thames Valley)

Not significant

Pass

Based on:

Overshading

Average

Windows facing South

2.00 m², No overhang

Air change rate

8.00 ach

Blinds/curtains

None

Criterion 4 – Building performance consistent with DER and DFEE rate

Party Walls

Type

U-value

Filled Cavity with Edge Sealing

0.00

W/m²K

Pass

Air permeability and pressure testing

3 Air permeability

Air permeability at 50 pascals

4.00 (design value)

Maximum

10.0

Pass

10 Key features

External wall U-value

0.13

W/m²K

Party wall U-value

0.00

W/m²K

Exposed floor U-value

0.12

W/m²K

Door U-value

0.85

W/m²K

Thermal bridging y-value

0.030

W/m²K

BASIC COMPLIANCE REPORT

Calculation Type: New Build (As Designed)

This report has not been submitted through the Elmhurst Energy members' portal, therefore results are subject to change when the dwelling is completed.