



Jon Skipper
Hants CC Property Services
By email only to:
Jon.skipper@hants.gov.uk

Frances Martin
Executive Director for Economic Growth
and Neighbourhood Services

Civic Offices, Bridge Street, Reading RG1 2LU
☎ 0118 937 3787

Our Ref: 210636/APPCON
Your Ref:

Direct: ☎ 0118 937 3338
e-mail: Richard.Eatough@reading.gov.uk

17 June 2021

Your contact is: Richard Eatough, Planning

Dear Jon,

Planning reference 210636/APPCON

Application for approval of details reserved by condition 3 (Schedule of materials) of application [consent] 201110

Katesgrove Primary School, Reading

I refer to the above application to discharge a planning condition and respond as follows.

Condition 3 (materials)

Condition 3 of Listed Building Consent 201110/LBC (and incidentally and for completeness, also Condition 3 of planning permission 201109/REG3 reads as follows:

3. Notwithstanding any notations as may appear on the approved plans in Condition 2 above, no commencement of the buttress wall works hereby permitted shall commence beyond foundation level until a schedule of the materials to be used in the construction of the works hereby permitted have been submitted to and approved in writing by the Local Planning Authority. The details shall confirm the type of bricks, the mortar (type, strength) and mortar strike.

You have confirmed the following with the agreement of our Conservation Officer, Bruce Edgar:

Brick - Wienerberger Class B Red Solid Engineering Brick

Mortar spec M12(i) lime cement mortar 1 Cement: 1 Lime:3 Sand as follows: ?

Mortar strike: flush joint.

I can confirm that Condition 3 of the above planning permission and listed building consent are hereby discharged providing that the works/ development are undertaken in accordance with the approved details.

Yours sincerely,

A handwritten signature in dark ink, consisting of a series of loops and a long horizontal stroke at the end.

Richard Eatough
Acting Development Management Team Leader