



ALBY Ltd

Unit 1, 49A Uttoxeter Old Road
Derby. DE1 1GE
Tel: 01332 342235

RESIN ANCHOR LOAD TEST.

CLIENT:-

WHP

CELL No:-

23408

SITE :-

TA CENTRE
BROCK BARRACKS
OXFORD ROAD
READING
RG30 1HW

.....
This is to certify the described resin anchors have been subjected to a pull test and
have achieved the stated load in accordance with the contract requirements.
.....

DESCRIPTION:

M12 A2 RESIN ANCHORS – 90mm EMBED
INTO BRICKWORK

HY270 RESIN

TEST LOAD:

M12 = 3 KN

DATE TESTED:

18TH MAY 2021

TEST EQUIPMENT:

HYDRO JAWS M2000 PRO SERIAL No: 12208A-04

Recalibration due date: 15/12/21

SIGNED:

PRINT:

D. HARRISON



POLE BRACKET LOCATIONS – M12 ANCHORS



POLE BRACKET LOCATIONS – M12 ANCHORS



POLE BRACKET LOCATIONS – M12 ANCHORS

