

INORGANIC ANALYSIS REPORT



0013

The Clay Company Ltd
26-28 Hammersmith Grove
London
W6 7BA

FAO: Mr. David Nelsen

Report of Tests on: Handmade Clay Brick

Your Reference: Woodbury Handmade

Lucideon Reference: (162875)-19668

Date Reported: 08-Jul-2016

Order Number: CC3193

Date Logged: 24-Jun-2016

Date(s) of Test(s): 07-Jul-2016 to 08-Jul-2016

Determination of Soluble Salts

BSEN772-5: 2016 with ICP Finish

Result(s)		Units	
Active Magnesium	Mg ²⁺	%	<0.005
Active Sodium	Na ⁺	%	0.009
Active Potassium	K ⁺	%	<0.005
Sodium + Potassium	Na ⁺ + K ⁺	%	<0.01
Water Soluble Magnesium	Mg ²⁺	%	<0.01
Classification Category			S2
Sulphate, Water Soluble	SO ₄	%	0.24
Mean of Duplicate Determinations			No
Sample Basis			Dried 110 deg C
UKAS Accredited			Yes

Sulphate has been measured on the same BSEN772-5 prepared extract solution, but it is outside the scope of the standard.

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation.

End of Test Report

C.E. Askey

Miss Clare Askey
Technician

This report is issued in accordance with the Conditions of Business of Lucideon Limited and relates only to the sample(s) tested. No responsibility is taken for the accuracy of the sampling unless this is done under our own supervision. This report shall not be reproduced in part without the written approval of Lucideon Limited, nor used in any way as to lead to misrepresentation of the results or their implications.

Lucideon is the trading name of Lucideon Limited. Registered in England No. 1960455.

Lucideon Limited
Queens Road, Penkhull
Stoke-on-Trent
Staffordshire ST4 7LQ

T +44 (0)1782 764428
enquiries@lucideon.com
www.lucideon.com