

Project: Apex Plaza 2B – 6B	Consultant:	Designer:	Date:	Sheet:	Revision:
Project No: M387/21	Charles D. Smith & Associates Ltd	CCS	20 th April 2021	1 of 2	3

SCHEDULE 19.2 - HVRF OUTDOOR UNITS

UNIT REF	MODEL NO.	NOISE dB (A)	REFRIGERANT	TOTAL COOLING (kW)	HEATING (kW)	INPUT POWER (kW)	MASS (kg)	DIMENSIONS (mm) L x W x H	NO.	SYSTEM INDEX
HPU 2B/1	PURY- EM350YNW-A1	64	R32	23.64	17.18	17.95	276	920 x 740 x 1858	1	357
HPU 2B/2	PURY- EM500YNW-A1	64.5	R32	45.2	21.97	20.24	348	1750 x 740 x 1858	1	510
HPU 2B/2a/HPU 2B/2b	PUZ-ZM250YKAR1	62	R32	19.5	7.85	7.81	138	1050 X 330 X 1338	2	-
HPU 3B/1	PURY- EM350YNW-A1	64	R32	23.64	17.18	17.95	276	920 x 740 x 1858	1	357
HPU 3B/2	PURY- EM500YNW-A1	64.5	R32	45.2	21.97	20.24	348	1750 x 740 x 1858	1	510
HPU 3B/3a/HPU 3B/3b	PUZ-ZM250YKAR1	62	R32	19.5	7.85	7.81	138	1050 X 330 X 1338	2	-
HPU 4B/1	PURY- EM350YNW-A1	64	R32	23.64	17.18	17.95	276	920 x 740 x 1858	1	357
HPU 4B/2	PURY- EM500YNW-A1	64.5	R32	45.2	21.97	20.24	348	1750 x 740 x 1858	1	510
HPU 4B/3a/HPU 4B/3b	PUZ-ZM250YKAR1	62	R32	19.5	7.85	7.81	138	1050 X 330 X 1338	2	-
HPU 5B/1	PURY- EM350YNW-A1	64	R32	23.64	17.18	17.95	276	920 x 740 x 1858	1	357
HPU 5B/2	PURY- EM500YNW-A1	64.5	R32	45.2	21.97	20.24	348	1750 x 740 x 1858	1	510
HPU 5B/3a/HPU 5B/3b	PUZ-ZM250YKAR1	62	R32	19.5	7.85	7.81	138	1050 X 330 X 1338	2	

- Notes:**
1. Equipment Based on Mitsubishi Electric, Jason Burrows: (M) 07917 388816 (E) Jason.burrows@meuk.mee.com
 2. The last number of the FCU reference identifies the outdoor unit to which it is connected
 3. HBC boxes to be water / R32

Project:	Apex Plaza 2B – 6B	Consultant:	Designer:	Date:	Sheet:	Revision:
Project No:	M387/21	Charles D. Smith & Associates Ltd	CCS	20th April 2021	2 of 2	3

SCHEDULE 19.2 - HVRF OUTDOOR UNITS

UNIT REF	MODEL NO.	NOISE dB (A)	REFRIGERANT	TOTAL COOLING (kW)	HEATING (kW)	INPUT POWER (kW)	MASS (kg)	DIMENSIONS (mm) L x W x H	NO.	SYSTEM INDEX
HPU 6B/1	PURY- EM350YNW-A1	64	R32	23.64	17.18	17.95	276	920 x 740 x 1858	1	-
HPU 6B/2	PURY- EM300YNW-A1	67	R32	20.0	17.18	17.95	236	920 x 740 x 1858	1	-
HPU 6B/3a/HPU 63/3b	PUZ-ZM250YKAR1	62	R32	19.5	7.85	7.81	138	1050 X 330 X 1338	2	-

- Notes:**
- 1. Equipment Based on Mitsubishi Electric, Jason Burrows: (M) 07917 388816 (E) Jason.burrows@meuk.mee.com**
 - 2. The last number of the FCU reference identifies the outdoor unit to which it is connected**
 - 3. HBC boxes to be water / R32**