



WARNING
GAS IN PLOT AREA
ENVIRONMENTAL ISSUES IN PLOT AREA

**JOINT BAY BY
SSEN**

**POTEND
SERVICE**

WARNING				UNCONTROLLED COPY Subject to Revision Master held at		UNCONTROLLED COPY Subject to Revision Master held at	
There may have been subsequent alterations to the surface level. First before must be taken to determine position and depth of cables. (SE U) if booklet from the HSE and also to determine existing underground services (available from the HSE)				Southern Electric Power Distribution plc. Registered Office No. 1 Forestry Place, 43 Forestry Road, Reading RG1 3JH.		Southern Electric Power Distribution plc. Registered Office No. 1 Forestry Place, 43 Forestry Road, Reading RG1 3JH.	
WHEN WORKING IN THE VICINITY OF OVERHEAD LINES THE HEALTH AND SAFETY GUIDANCE NOTE ONE SHOULD BE CONSULTED. (AVAILABLE FROM THE HSE)				The map has been made by us with the authority of Southern Electricity Networks plc, pursuant to the provisions of the Electricity Act 1989 and the Electricity Regulations 2002. It is not to be used for any other purpose without the prior written consent of Southern Electricity Networks plc. Southern Electricity Networks plc Registered Office No. 1 Forestry Place, 43 Forestry Road, Reading RG1 3JH.		The map has been made by us with the authority of Southern Electricity Networks plc, pursuant to the provisions of the Electricity Act 1989 and the Electricity Regulations 2002. It is not to be used for any other purpose without the prior written consent of Southern Electricity Networks plc. Southern Electricity Networks plc Registered Office No. 1 Forestry Place, 43 Forestry Road, Reading RG1 3JH.	
NORMAL DEPTH TO THE TOP OF THE CABLE WHEN LAID				L.V. MAINS & Services		Grid Ref: SU71917271	
services l.v. h.v. e.h.v.				READING 01189-128500		Scale: 1:500	
FOOTPATH 0.40m 0.45m 0.60m 0.75m						Date: 17/04/2019	
ROAD CROSSING 0.60m 0.60m 0.75m 0.90m							
L.V./services - up to 1000V.							
h.v. - over 1000V. to 11,000V.							
e.h.v. - 22,000V. to 132,000V.							

WARNING