

BLOCK COMPLIANCE

Calculation Type: New Build (As Designed)



Property and Energy
Services Ltd.

Block Reference	3567	Issued on Date	27/04/2020
Block Name	Henley Road Phase 2		
Assessor Details	Mr. Ian Lloyd, Property and Energy Services Limited, Tel: 01367240212, ianl@propertyandenergy.co.uk		Assessor ID
			H044-0001
Client	Lloyd Anthony, Lloyd		

Block Compliance Report - DER

Block Reference: 3567		Block Name: Henley Road Phase 2		
Property-Assessment Reference	Multiplier	Floor Area (m²)	DER (kgCO₂/m²)	TER (kgCO₂/m²)
3567-1-3567-1	1	140.68	10.23	14.36
3567-3-3567-3	1	140.68	10.27	14.35
3567-5-3567-5	1	138.23	9.83	13.71
3567-7-3567-7	1	138.23	13.68	13.71
3567-8-3567-8	1	138.23	12.93	13.10
3567-2-3567-2	1	140.68	10.23	14.36
3567-4-3567-4	1	140.68	10.27	14.35
3567-6-3567-6	1	138.23	9.83	13.71
3567-9-3567-9	1	138.23	13.68	13.71
Totals:	9	1253.87	100.95	125.38
Average DER = 11.21 kgCO₂/m²			PASS	
Average TER = 13.93 kgCO₂/m²				

Block Compliance Report - DFEE

Block Reference: 3567		Block Name: Henley Road Phase 2		
Property-Assessment Reference	Multiplier	Floor Area (m²)	DFEE (kWh/m²/yr)	TFEE (kWh/m²/yr)
3567-1-3567-1	1	140.68	38.37	47.16
3567-3-3567-3	1	140.68	38.52	47.09
3567-5-3567-5	1	138.23	36.69	43.45
3567-7-3567-7	1	138.23	36.69	43.45
3567-8-3567-8	1	138.23	33.05	39.75
3567-2-3567-2	1	140.68	38.37	47.16
3567-4-3567-4	1	140.68	38.52	47.09
3567-6-3567-6	1	138.23	36.69	43.45
3567-9-3567-9	1	138.23	36.69	43.45
Totals:	9	1253.87	333.59	402.06
Average DFEE = 37.08 kWh/m²/yr			PASS	
Average TFEE = 44.69 kWh/m²/yr				