



Construction Notes:

1. Do not scale from this drawing.
2. All dimensions in metres.
3. All levels relate to ordnance datum.
4. This drawing is based on the latest Architectural planning layout and shall be read in conjunction with all other relevant longitudinal sections and construction drawings.
5. Any discrepancies with any of the drawings shall be reported to MJA Consulting Engineer.
6. The level and location of all existing services shall be verified on site by the Contractor before commencing any construction work.
7. Contractor must comply with all current legislation relating to CDM, Health and Safety and COSHH.
8. All material in excess of 20kg (i.e. kerbs, manhole units cover etc.) shall be mechanically lifted and laid where possible at all times.
9. Manholes, sewers, headwalls and other structures intended to convey surface water or sewerage are to be constructed in accordance with the Water Authorities Association specification "Sewers for Adoption" 7th edition and to Thames Water's specification and addendum.
10. Gullies, gully connections, drains, manholes, catchpits, soakaways, headwalls and other drainage structures intended to convey highway water are to be constructed in accordance with the specification issued by Oxfordshire County Council.
11. All foul and storm water drains which are not to be adopted as public sewers under a section 104 agreement shall be constructed using uPVC pipes or similar approved, bedded and backfilled in accordance with the manufacturers instructions and to the Building Regulations Part H, BS EN 752 & B.R.E. SD1.
12. All building drainage to be 100mm dia. laid at a minimum gradient of 1 in 60 (FW) and 1 in 80 (SW) unless otherwise shown.
13. Sewers and drains of different diameters should be laid side to side.
14. Inspection chambers on private drains shall be non-access preformed polypropylene.

Depth to invert	Minimum size
< 1.2m	DN450
> 1.2m	DN600

In accordance with the Building Regulations Part H & BS EN 752.
15. Position of soil pipes, stubstacks, WC outlets rainwater downpipes etc positions shall be checked against architects house type drawings to ensure compatibility.
16. Where bare inlet gullies are used they should be roddable.
17. All stub stacks to be fitted with air admittance valve where branch drain exceeds 12m except at head of run.
18. Rainwater downpipes to be connected directly to drains via removable adapter to permit access for rodding.
19. Positions of yard and house gullies are nominal and may be adjusted on site, a/c drains to be installed at the end of all drives falling towards the public highway. All gully gratings in drives and parking areas should be of sufficient strength to withstand vehicular loading.
20. Unfils or sleeves are to be provided for drains passing through foundation brickwork.
21. All gully connections to be 150 dia. uPVC ultrabir or similar.
22. All gully connections other than at manholes to be "Y" junctions.
23. All drain runs are to be flushed through and building materials removed where necessary at the time of final test by Building Inspector and prior to occupation.
24. All soakaways to be positioned a minimum of 5.0m from buildings (where utilised).
25. All finished floor levels are shown on the drawing for guidance only and may need to be adjusted on site. However there is to be no deviation without prior approval.
26. All drives are to have a crossfall or gradient of 1:40 minimum. Maximum drive gradient on down slope to be 1 in 10 and 1 in 8 on up slopes.
27. Continuous edging to be laid at rear of service margin.

KEY:

- Proposed Adoptable Sewers:
Foul sewer
Storm sewer
- Highway Gully
- Proposed Private Drainage:
Drop SVP within Block 1
- Foul drain
Drop RWP within Block 1
Storm drain
Rodding eye
Yard gully
A/c drain
Permeable Diffuser Unit
Storage Tank
- Permeable trench

All private inspection chambers shall be polypropylene non-access chambers in accordance with The Building Regulations, Part H.

Chamber sizes:
Depth to invert <0.6m DN300
Depth to invert >0.6m DN475
Invert levels shown thus: F10.00 S10.00

Finished floor levels shown thus: FFL 10.00

Fall Arrows

Proposed Levels
Primary Access
Secondary Access
Stepped Cavity Tray
External Brickwork

Tanking
Retaining Wall

6m Street Lighting to lantern spec below

R & L 6m Columns

Luminaire A Data

Supplier	Holophane Europe
Type	VMXL634-V1.F401
Lamp(s)	LED c.3000LM - 4000K
Lamp Flux (klm)	3.62
File Name	VMXL634-V1.F401.IES
Maintenance Factor	0.81
Imax70.80.90(cd/klm)	461.8 69.9 0.0
Lamp S/P Ratio	1.50
No. in Project	19

PRELIMINARY

J	21.08.19	Plot 21 foul drainage amended and levels adjusted for footpath link	JS
H	03.07.19	Block 2-5 Private Drainage amended	JS
F	20.03.19	Block 1 Private Drainage amended	JS
F	20.03.19	Drainage to NHS Steris building added	JS
E	17.01.19	Design updated to clients comments	JS
D	31.10.18	Design updated to client comments	JS
C	19.10.18	Block 1 sub structure updated and clients comments included	JS
B	12.10.18	Block 1 sub structure added	JS
A	10.09.18	Street lighting added, size added to tank & spot levels added	JS
REV. No.	DATE	DESCRIPTION	INITIALS

Client
Portman Road
Reading

CIVIL AND STRUCTURAL ENGINEERS
Monarch House, Barton Lane,
Abingdon, Oxon, OX14 3NB
Tel: 01235 555173
Fax: 01235 523226

Title	Engineering Layout Sheet 1	Scale	1:250 @ A0	Date	Aug 18	Drawing No.	5672:01	Rev	J
Checked	AMc	Drawn	JS						