

EXTENSION & NEW BUILD CONSTRUCTION

TRENCH FOUNDATION
Provide 750mm x 600mm trench fill foundations, concrete mix to conform to BS EN 206-1 and BS 8500-2. All foundations to be a minimum of 1000mm below ground level, exact depth to be agreed on site with Building Control Officer to suit site conditions. All constructed in accordance with 2004 Building Regulations A1/2 and BS 8004:1986 Code of Practice for Foundations. Ensure foundations are constructed below invert level of any adjacent drains. Base of foundations supporting internal walls to be min 600mm below ground level. Sulphate resistant cement to be used if required. Please note that should any adverse soil conditions or difference in soil type be found or any major tree roots in excavations, the Building Control Officer is to be contacted and the advice of a structural engineer should be sought.

SUSPENDED BLOCK AND BEAM FLOOR
Remove top soil and vegetation, apply weed killer -
The underside of beams not less than 150mm above the top of the ground. PCC beams to be supplied and fixed to beam manufacturer's plan, layout and details (details and calculations to be sent to Building Control and approved before works commence). Minimum bearing 100mm onto DPC and load bearing walls. Provide concrete blocks to BS6073 pt.1, wet and grout all joints with 1:4 cement/sand mix. Provide double beams below non-load bearing partitions. Lay 1200g DPM/radon barrier, with 300mm laps double welted and taped at joints and service entry points using radon gas proof tape, over beam and block floor. Lay floor insulation over DPM, 150mm Kingspan Kooltherm K103 applied as a rigid material. Lay 500g separating layer over insulation and provide 75mm sand/cement screed over and prepare for floor finishes as required. The top surface of the ground cover under the building shall be above the finished level of the adjoining ground.
Ventilation - Provide cross-ventilation of the under floor to outside air by ventilators in at least 2 opposite external walls of the building. Ventilation openings having an opening area of 1500mm² per metre run of perimeter wall or 500mm² per square metre of floor area, whichever is the greater. Sleeper walls shall be of honeycombed construction or have provision for distribution of ventilation.

BEAMS AND FIRE PROTECTION
Engineer's Structural calculations and details are to be provided for all beams, roof, lintels, joists, bearings, padstones and any other load bearing elements before works commence on site. New steel beams to be encased in 12.5mm Gyproc FireLine board with staggered joints, Gyproc FireCase or painted in Nullifire S or similar intumescent paint to provide 1/2 hour fire resistance as agreed with Building Control. All fire protection to be installed as detailed by specialist manufacturer.

DOORS AND WINDOWS

ESCAPE WINDOWS - EEW on plan
Provide emergency egress windows to any newly created first floor habitable rooms and ground floor inner rooms. Windows to have an unobstructed openable area of 450mm high x 450mm wide, minimum 0.33m sq. The bottom of the openable area should be not more than 1100mm above the floor. The window should enable the person to reach a place free from danger from fire.

ROOF LIGHTS
Min U-value of 1.6 W/m²K.
Roof-lights to be double glazed with 16mm argon gap and soft low-E glass. Window Energy Rating to be Band C or better. Roof lights to be fitted in accordance with manufacturer's instructions with rafters doubled up to sides and suitable flashings etc.

SAFETY GLAZING - TG (Toughened Glass on plan)
All glazing in critical locations to be toughened or laminated safety glass to BS 6206, BS EN 14179 or BS EN ISO 12543-1:2011 and Part K (Part N in Wales) of the current Building Regulations, i.e. within 1500mm above floor level in doors and side panels within 300mm of door opening and within 800mm above floor level in windows.

NEW AND REPLACEMENT WINDOWS
New and replacement windows to be double glazed with 16mm argon gap and soft coat low-E glass. Window Energy Rating to be Band C or better and to achieve U-value of 1.6 W/m²K. The door and window openings should be limited to 25% of the extension floor area plus the area of any existing openings covered by the extension.

NEW AND REPLACEMENT DOORS
New and replacement doors to achieve a U-Value of 1.80W/m²K. Glazed areas to be double glazed with 16mm argon gap and soft low-E glass. Glass to be toughened or laminated safety glass to BS 6206, BS EN 14179 or BS EN ISO 12543-1:2011 and Part K (Part N in Wales) of the current Building Regulations.

BACKGROUND AND PURGE VENTILATION
Background ventilation - Controllable background ventilation via trickle vents to BS EN 13141-3 within the window frame to be provided to new habitable rooms at a rate of min 5000mm²; and to kitchens, bathrooms, WCs and utility rooms at a rate of 2500mm²
Purge ventilation - New Windows/rooftlights to have openable area in excess of 1/20th of their floor area, if the window opens more than 30° or 1/10th of their floor area if the window opens less than 30°
Internal doors should be provided with a 10mm gap below the door to aid air circulation.
Ventilation provision in accordance with the Domestic Ventilation Compliance Guide.

Door Schedule - Ground Floor

Ref.	Location	Str. opening	Door leaf	Notes
D00-01	Entrance	1000 x 2100	-	LG, FT
D00-02	WC	834 x 2025	762 x 1981	
D00-03	Dining	TO SUIT EX.	-	LG, pair

Window Schedule - Ground Floor

Ref.	Location	Str. opening	Notes
W00-01	Porch	480 x 1200	LG
W00-02	Porch	480 x 1200	LG
W00-03	Play room	685 x 1855	LG



colony architects ltd is a collaboration of architects and designers with an agenda to find out more visit our beautiful web site

www.colonyarchitects.com
contact: design@colonyarchitects.com

07990 515572 07779 255525 01253 515572
moking road guilford guilford

project: 18 Chiltern Road, Reading, RG4 3HT

client: Laura and Rob York

drawing title: Notes & Schedules

project: 248- 70-00 revision: T1

date: Feb 2019 status: Tender-draft

scale: 1:50 size: A3 author: NF checked: EGM

© 2019 colony architects

colony architects

RIBA