



**56 BRADMORE WAY
LOWER EARLEY
READING
BERKS, RG6 4DS**

TEL: 0845 166 8035
email: jas.dhalay@ntlworld.com

23/11/2019

FAO
TOM HUGHES
PLANNING OFFICER
Reading Borough Council
Civic Offices, Level 1 North
Bridge Street
Reading
RG1 2LU

Dear Sir,

Re: 93 Wokingham Road - 191543/FUL

With regard to your email of 03/10/2019 please note that in accordance with the DEFRA Guidance on Odour Control 2005 Chapter 4.7, the client is recommended to install:

1. Fine Pre-Filter
2. Activated Carbon Filter

This is to counter any Odour nuisance. The document is attached.

Kind Regards

Jasmail Dhalay BSc