



Company / Installer		Job Address		Client / LandLord	
Engineer	Stefan Wasylciw	Name		Name	Mr Spencer Chaplin
Company	Peppard Heating & Plumbing	Address	187A	Company	
Address	41		Caversham Rd	Address	13
	Surley Row		Reading		Brooklyn Drive
	Reading		Berkshire		Reading
	BERKSHIRE	Post Code	RG1 8BD		Berkshire
Post Code	RG4 8 LU	Tel No.		Post Code	RG4 8SR
Tel No.	07956566317			Tel No.	
Gas Safe Reg	225616			Mob. No.	07831315931
ID Card No.	225616				

Appliance Details		Inspection Details			
Type:	Water Heater	Model:	140 Litre Direct	Indirect, or Direct:	direct
Make:	Heatrae Sadie	Serial No:	GRE181900021AN	Gas boiler and/or Solar, or Immersion Heaters	immersion
Location:	Compartment			Capacity (Ltrs)	140
				Makers Warning label attached:	NA
				Inlet water pressure:	3 bar
				Flow Rate:	18
				Fully commissioned:	Yes

Content					
Hot Water Storage Vessel Operating Details					
System operating pressure:	3 bar	Bar	Operating temperature of temperature relief valve:	90 c	°C
Operating pressure of expansion vessel:	8 bar	Bar	Operating temperature:	58	°C
Operating pressure of expansion valve:	8 bar	Bar	Pressure of combined temperature and pressure relief valve:	10	Bar
Discharge Pipework (D1) - relief valve to tundish					
Nominal size of D1:	15	mm	Size of manifold, if more than one discharge:		
Length of D1:	300	mm	Is tundish installed within the same location as the hot water storage vessel:	Yes	
Number of discharges:	1		Is the tundish visible?	Yes	
			Is automatic means of identifying discharge installed?	NA	
Discharge Pipework (D2) - tundish to point of termination					
Nominal size of D2:	22	mm	Does the pipework fall continuously to point of termination:	Yes	
Pipework material:	copper		Method of termination:	Low Level	
Does pipework have a minimum vertical length of 300mm from tundish:	Yes		Method of termination satisfactory?	Yes	
Comment					

Signatures			
Issued by: Signed		Received by: Signed	
Print Name:	Stefan Wasylciw	Print Name:	S Chaplin
		Date	11-Jul-2019