

Savills
Hawker House
5-6 Napier Court
Napier Road
RG1 8BW

Giorgio Framalicco
Head of Planning, Development
& Regulatory Services

Civic Offices, Bridge Street,
Reading, RG1 2LU

☎ 0118 9373787

Our Ref: 181882

Your Ref: PP-07382984

Direct ☎: 0118 9372461

e-mail: julie.williams@reading.gov.uk

26 November 2018

Your contact is: Julie Williams, Planning

Dear Ms Walters,

TOWN AND COUNTRY PLANNING ACT 1990

Application Reference: 181882

Application type: Approval of Conditions

Address: Site Of Worton Grange Imperial Way Reading

Proposal: Application for discharge of condition 62 - air conditioning and refrigeration plant details - of planning permission 151944.

I refer to your application as described above.

Following the submission on 21st November of an amended version of the Plant Noise Breakout Assessment, which now incorporates confirmation that the target plant noise limit will be achieved with the proposed acoustic enclosure, in addition to the specifications for the proposed acoustic enclosure sent in on 12th November I can confirm that the information submitted is acceptable to allow the discharge of this planning condition.

Full compliance will require the approved noise attenuation measures to be installed and appropriately maintained as detailed in the approved documents.

Please note that it is the responsibility of the developer to ensure that all relevant conditions are complied with during the construction and/or subsequent use of the development.

Should you wish to discuss this matter further, please contact me by email or the direct line as above.

Yours sincerely



Julie Williams
Area Planning Manager