

Project: 1-2 Market Place, Reading
Spec: Attenuator Schedule
Client: City Pubs
Date: 23.04.2018
Ref: CP9497-SH-M05
Revision: 01



Ref.	System Reference	Location	Code	Length mm	Width mm	Dia/Height mm	Weight kg	Flow l/s	Pressure Drop Pa
ATT01	KEF01	Third Floor Plantroom	PG01U/1K/L/SM	1215	-	400	26	1120	0
ATT02	KEF02	Third Floor Plantroom	PG01U/1K/L/M	1215	-	450	28	1260	0
ATT03	KEF03	Third Floor Plantroom	PG01U/1L/L/M	1220	-	500	46	1540	0
ATT04	AHU01 Intake	Third Floor Plantroom	SG01V/3C/L/S	1500	1545	855	196	3100	38
ATT05	AHU01 Supply	Third Floor Plantroom	SG01V/3C/L/S	1500	1545	855	196	3100	38
ATT06	HRU01 Supply	Third Floor Plantroom	PG01U/1K/L/	1215	-	400	26	500	0
ATT07	HRU01 Extract	Third Floor Plantroom	PG01U/1K/L/	1215	-	400	26	500	0