

Project: 1-2 Market Place, Reading
Spec: Fan Schedule
Client: City Pubs
Date: 19.04.2018
Ref: CP9497-SH-M02
Revision: 01



Ref.	System	Mounted	Type	ATEX Rated	Control	Ancillaries	Room Flow l/s	Fan Flow l/s	Pa	Qty	Manufacturer	Model Ref	Dimensions (L x W x H) mm	Weight kg	Electrical	
EF01	Basement Toilet Extract	Internal	Inline Centrifugal	No	PIR and run-on timer	-	72	120	125	1	Vent Axia	ACM150T	200x307x256	-	1	0.21
EF02	Pizza Oven Extract	External	Inline	No	on/off and speed control	-	-	-	-	1	-	-	-	-	-	-
EF03	Ground Floor Disabled Toilet	Internal	Wall Mounted	No	light switch and run-on timer	-	8	9	25	1	Vent Axia	Lo-Carbon Centra T	160x160x3.5	-	1	-
EF04	Third Floor Male Toilet	Internal	Wall Mounted	No	light switch and run-on timer	-	8	9	25	1	Vent Axia	Lo-Carbon Centra T	160x160x3.5	-	1	-
EF05	Third Floor Disabled Toilet	Internal	Wall Mounted	No	light switch and run-on timer	-	8	9	25	1	Vent Axia	Lo-Carbon Centra T	160x160x3.5	-	1	-
EF06	Third Floor Female Toilet	Internal	Wall Mounted	No	light switch and run-on timer	-	8	9	25	1	Vent Axia	Lo-Carbon Centra T	160x160x3.5	-	1	-
SF01	Basement Supply	Internal	Inline Centrifugal	No	PIR and run-on timer	-	72	120	125	1	Vent Axia	ACM150T	200x307x256	-	1	0.21
KEF01	Kitchen 4 Extract	Internal	-	No	on/off and speed control	Flexible Connections	1120	1960	400	1	SystemAir	MUB 042 500D4 IE2	670x670x670	64	3	2.87
KEF02	Kitchen 3 Extract	Internal	-	No	on/off and speed control	Flexible Connections	1260	1960	400	1	SystemAir	MUB 042 500D4 IE2	670x670x670	64	3	2.87
KEF03	Kitchen 2 Extract	Internal	-	No	on/off and speed control	Flexible Connections	1540	3000	400	1	SystemAir	MUB 062 560D4 IE2	800x800x800	92	3	4.27