

DRAFT

© EAA - EMRE AROLAT ARCHITECTURE


DO NOT SCALE FROM THIS DRAWING. VERIFY ALL DIMENSIONS ON SITE. DRAWING SHOULD BE READ IN CONJUNCTION WITH INFORMATION FROM ALL OTHER DESIGN CONSULTANTS AND CONTRACTORS. ALL DRAWINGS IN DIGITAL FORMAT ARE FOR REFERENCE ONLY. PAPER COPIES ARE AVAILABLE ON REQUEST.

OPTION 1

450mm DEEP x 250mm WIDE
downstand beam required to span
8500mm span on all levels.
'Red' column to remain at 600mm
x250mm size as per other columns.

OPTION 2

Column line setting out to be
reverted to that shown in Fluid
Sketch 25206_180424_RN_SCH03
and comments in
25206_180502_RN_SCH04,
allowing for shorter span. This will
require no RC downstand beam.
Columns to be located on Gridlines
D&F, not E.



10	27.04.18	SS	BUILDING PARAMETERS & LAYOUTS
09	09.04.18	PB	TENURE, LANDSCAPE ADDED, DRAWING NUMBERS AND ANNOTATION
08	04.04.18	KU	BUILDING PARAMETERS & LAYOUTS
07	21.03.18	KU	BUILDING PARAMETERS & LAYOUTS
06	08.03.18	KU	PD LAYOUTS ADDED
05	07.03.18	AZ	MEWS ADDED / GENERAL
04	23.02.18	AZ	GENERAL AMENDMENTS
03	20.02.18	AZ	GENERAL AMENDMENTS
02	15.02.18	AZ	GENERAL AMENDMENTS
01	14.02.18	AZ	FOOTPRINT REDUCED
NO	DATE	BY	REVISION

DRAWING TITLE
PROPOSED LEVEL 6 PLAN

PROJECT NAME
CLARENDON HOUSE

EAA
EMRE AROLAT ARCHITECTURE
NEW YORK-LONDON-ISTANBUL
40 BOWLING GREEN LANE, LONDON UK
EC1R 0NE T.020 7415 7235-36-37
london@emrearolat.com - www.emrearolat.com

CLIENT
READING HEIGHTS LIMITED

PROJECT NO	DRAWN	ISSUE DATE
220	AZ	11.01.2018
	CHECKED	SCALE
	-	1/200@A3

BLOCK	STAGE	DRAWING NO	REVISION
BC	2	22-16	10

FLUID COMMENTS

10/05/2018

PHASE 3 FRAMING COORDINATION - REV1

DRG NO: SCH05
JOB NUMBER: 25206
DRN: RN
CHK: KW



Extend core walls as shown

Fluid note large opening (approx 2.4m
high x 0.9m wide) to be formed within
core wall following conversation with
A.Zorlu (EAA).
Link beam, likely highly reinforced,
required to tie core walls together
above and below opening on all levels.

Column sizes to remain
at 600mmx250mm
sections on all levels.

DRAFT

© EAA - EMRE AROLAT ARCHITECTURE


DO NOT SCALE FROM THIS DRAWING. VERIFY ALL DIMENSIONS ON SITE. DRAWING SHOULD BE READ IN CONJUNCTION WITH INFORMATION FROM ALL OTHER DESIGN CONSULTANTS AND CONTRACTORS. ALL DRAWINGS IN DIGITAL FORMAT ARE FOR REFERENCE ONLY. PAPER COPIES ARE AVAILABLE ON REQUEST.

OPTION 1

450mm DEEP x 250mm WIDE
downstand beam required to span
8500mm span on all levels.
'Red' column to remain at 600mm
x250mm size as per other columns.

OPTION 2

Column line setting out to be
reverted to that shown in Fluid
Sketch 25206_180424_RN_SCH03
and comments in
25206_180502_RN_SCH04,
allowing for shorter span. This will
require no RC downstand beam.
Columns to be located on Gridlines
D&F, not E.



10	27.04.18	SS	BUILDING PARAMETERS & LAYOUTS
09	09.04.18	PB	TENURE, LANDSCAPE ADDED, DRAWING NUMBERS AND ANNOTATION
08	04.04.18	KU	BUILDING PARAMETERS & LAYOUTS
07	21.03.18	KU	BUILDING PARAMETERS & LAYOUTS
06	08.03.18	KU	PD LAYOUTS ADDED
05	07.03.18	AZ	MEWS ADDED / GENERAL
04	23.02.18	AZ	GENERAL AMENDMENTS
03	20.02.18	AZ	GENERAL AMENDMENTS
02	15.02.18	AZ	GENERAL AMENDMENTS
01	14.02.18	AZ	FOOTPRINT REDUCED
NO	DATE	BY	REVISION

DRAWING TITLE
PROPOSED LEVEL 7 PLAN

PROJECT NAME
CLARENDON HOUSE

EAA
EMRE AROLAT ARCHITECTURE
NEW YORK-LONDON-ISTANBUL
40 BOWLING GREEN LANE, LONDON UK
EC1R 0NE T.020 7415 7235-36-37
london@emrearolat.com - www.emrearolat.com

CLIENT
READING HEIGHTS LIMITED

PROJECT NO	DRAWN	ISSUE DATE
220	AZ	11.01.2018
	CHECKED	SCALE
	-	1/200@A3

BLOCK	STAGE	DRAWING NO	REVISION
BC	2	22-17	10

FLUID COMMENTS

10/05/2018

PHASE 3 FRAMING COORDINATION - REV1

DRG NO: SCH05
JOB NUMBER: 25206
DRN: RN
CHK: KW



Extend core walls as shown

Fluid note large opening (approx 2.4m
high x 0.9m wide) to be formed within
core wall following conversation with
A.Zorlu (EAA).
Link beam, likely highly reinforced,
required to tie core walls together
above and below opening on all levels.

Column sizes to remain
at 600mmx250mm
sections on all levels.

DRAFT

© EAA - EMRE AROLAT ARCHITECTURE


DO NOT SCALE FROM THIS DRAWING. VERIFY ALL DIMENSIONS ON SITE. DRAWING SHOULD BE READ IN CONJUNCTION WITH INFORMATION FROM ALL OTHER DESIGN CONSULTANTS AND CONTRACTORS. ALL DRAWINGS IN DIGITAL FORMAT ARE FOR REFERENCE ONLY. PAPER COPIES ARE AVAILABLE ON REQUEST.

OPTION 1

450mm DEEP x 250mm WIDE
downstand beam required to span
8500mm span on all levels.
'Red' column to remain at 600mm
x250mm size as per other columns.

OPTION 2

Column line setting out to be
reverted to that shown in Fluid
Sketch 25206_180424_RN_SCH03
and comments in
25206_180502_RN_SCH04,
allowing for shorter span. This will
require no RC downstand beam.
Columns to be located on Gridlines
D&F, not E.



10	27.04.18	SS	BUILDING PARAMETERS & LAYOUTS
09	09.04.18	PB	TENURE, LANDSCAPE ADDED, DRAWING NUMBERS AND ANNOTATION
08	04.04.18	KU	BUILDING PARAMETERS & LAYOUTS
07	21.03.18	KU	BUILDING PARAMETERS & LAYOUTS
06	08.03.18	KU	PD LAYOUTS ADDED
05	07.03.18	AZ	MEWS ADDED / GENERAL
04	23.02.18	AZ	GENERAL AMENDMENTS
03	20.02.18	AZ	GENERAL AMENDMENTS
02	15.02.18	AZ	GENERAL AMENDMENTS
01	14.02.18	AZ	FOOTPRINT REDUCED
NO	DATE	BY	REVISION

DRAWING TITLE
PROPOSED LEVEL 8 PLAN

PROJECT NAME
CLARENDON HOUSE

EAA
EMRE AROLAT ARCHITECTURE
NEW YORK-LONDON-ISTANBUL
40 BOWLING GREEN LANE, LONDON UK
EC1R 0NE T.020 7415 7235-36-37
london@emrearolat.com - www.emrearolat.com

CLIENT

READING HEIGHTS LIMITED

PROJECT NO	DRAWN	ISSUE DATE
220	AZ	11.01.2018
	CHECKED	SCALE
	-	1/200@A3

BLOCK	STAGE	DRAWING NO	REVISION
BC	2	22-18	10

Extend core walls as shown

Fluid note large opening (approx 2.4m
high x 0.9m wide) to be formed within
core wall following conversation with
A.Zorlu (EAA).
Link beam, likely highly reinforced,
required to tie core walls together
above and below opening on all levels.

Column sizes to remain
at 600mmx250mm
sections on all levels.

FLUID COMMENTS

10/05/2018

PHASE 3 FRAMING COORDINATION - REV1

DRG NO: SCH05
JOB NUMBER: 25206
DRN: RN
CHK: KW



DRAFT

© EAA - EMRE AROLAT ARCHITECTURE


DO NOT SCALE FROM THIS DRAWING. VERIFY ALL DIMENSIONS ON SITE. DRAWING SHOULD BE READ IN CONJUNCTION WITH INFORMATION FROM ALL OTHER DESIGN CONSULTANTS AND CONTRACTORS. ALL DRAWINGS IN DIGITAL FORMAT ARE FOR REFERENCE ONLY. PAPER COPIES ARE AVAILABLE ON REQUEST.

OPTION 1

450mm DEEP x 250mm WIDE
downstand beam required to span
8500mm span on all levels.
'Red' column to remain at 600mm
x250mm size as per other columns.

OPTION 2

Column line setting out to be
reverted to that shown in Fluid
Sketch 25206_180424_RN_SCH03
and comments in
25206_180502_RN_SCH04,
allowing for shorter span. This will
require no RC downstand beam.
Columns to be located on Gridlines
D&F, not E.



10	27.04.18	SS	BUILDING PARAMETERS & LAYOUTS
09	09.04.18	PB	TENURE, LANDSCAPE ADDED, DRAWING NUMBERS AND ANNOTATION
08	04.04.18	KU	BUILDING PARAMETERS & LAYOUTS
07	21.03.18	KU	BUILDING PARAMETERS & LAYOUTS
06	08.03.18	KU	PD LAYOUTS ADDED
05	07.03.18	AZ	MEWS ADDED / GENERAL
04	23.02.18	AZ	GENERAL AMENDMENTS
03	20.02.18	AZ	GENERAL AMENDMENTS
02	15.02.18	AZ	GENERAL AMENDMENTS
01	14.02.18	AZ	FOOTPRINT REDUCED
NO	DATE	BY	REVISION

DRAWING TITLE
PROPOSED LEVEL 9 PLAN

PROJECT NAME
CLARENDON HOUSE

EAA
EMRE AROLAT ARCHITECTURE
NEW YORK-LONDON-ISTANBUL
40 BOWLING GREEN LANE, LONDON UK
EC1R 0NE T.020 7415 7235-36-37
london@emrearolat.com - www.emrearolat.com

CLIENT
READING HEIGHTS LIMITED

PROJECT NO	DRAWN	ISSUE DATE
220	AZ	11.01.2018
	CHECKED	SCALE
	-	1/200@A3

BLOCK	STAGE	DRAWING NO	REVISION
BC	2	22-19	10

Extend core walls as shown

Fluid note large opening (approx 2.4m
high x 0.9m wide) to be formed within
core wall following conversation with
A.Zorlu (EAA).
Link beam, likely highly reinforced,
required to tie core walls together
above and below opening on all levels.

Column sizes to remain
at 600mmx250mm
sections on all levels.

FLUID COMMENTS

10/05/2018

PHASE 3 FRAMING COORDINATION - REV1

DRG NO: SCH05
JOB NUMBER: 25206
DRN: RN
CHK: KW

