

ECE Planning Limited  
Brooklyn Chambers  
11 Goring Road  
Worthing  
BN12 4AP

Attn: S Sykes

Giorgio Framalico  
Head of Planning, Development  
& Regulatory Services  
Civic Offices, Bridge Street,  
Reading, RG1 2LU

☎ 0118 9373787

Our Ref: 180559  
Your Ref: PP-06860078

Direct ☎: 0118 9372993  
e-mail: [Ralph.chakadya@reading.gov.uk](mailto:Ralph.chakadya@reading.gov.uk)

21 May 2018

Your contact is: Mr Ralph Chakadya, Planning

Dear Mr Sykes,

## TOWN AND COUNTRY PLANNING ACT 1990

**Application Reference:** 180559

**Application type:** Approval of Conditions

**Address:** The Wren School 61-63 Bath Road Reading RG30 2BB

**Proposal:** Discharge of condition 42 of planning permission 151175

I refer to your application as described above.

### Condition 15 - Noise assessment

Following consultations with the Council's Environmental Health Officer, I can confirm that the noise assessment submitted by SRL dated 28 February 2018 has been carried out in accordance with BS4142:2014 and the methodology has been correctly applied. The assessment concludes that the specific noise level of the proposed plant will not exceed -10dB below the background noise and the rating level does not exceed the background noise so adverse impact on the local noise climate is unlikely subject to some of the items of plant requiring attenuators to be fitted to the exhaust:


#### Item of Plant Noise Reduction Comments

- AHU01 20 dBA Attenuator to the exhaust only
- AHU02 18 dBA Attenuator to the exhaust only
- AHU03 12 dBA
- AHU04 20 dBA Attenuator to the exhaust only
- EF01 20 dBA
- EF02 15 dBA
- EF03 9 dBA

The plant shall be installed as recommended within the submitted noise assessment.

Condition 42 is hereby discharged.

Yours sincerely



ppMr Ralph Chakadya  
Planning Officer