

RGP Design Limited		Page 1
Metro House Northgate Chichester PO19 1BE	1-3 Castle Crescent Reading	
Date 08/03/2018 File D1368 Existing.mdx	Designed by SPB Checked by LDF	
XP Solutions	Network 2016.1	

Summary of Results for 15 minute 30 year Winter (Storm)

Margin for Flood Risk Warning (mm) 300.0 DVD Status OFF
 Analysis Timestep Fine Inertia Status OFF
 DTS Status ON

		Water	Surcharged	Flooded		Pipe	
	US/MH	Level	Depth	Volume	Flow / Overflow	Flow	
PN	Name	(m)	(m)	(m³)	Cap.	(l/s)	Status
1.000	1	57.676	-0.134	0.000	0.58	57.1	OK
1.001	2	57.462	-0.165	0.000	0.41	56.4	OK
1.002	3	57.127	-0.133	0.000	0.59	57.3	OK