



SCANNED
8TH DEC 17

08 DEC 2017

Mr N Bradford

Developer Services

6 Octagon Business Park
Hospital Road
Norwich
NR13 5FH

DS ref DS4042650
Our ref 1015536590
Name Carol Barefoot
Phone 0800 009 3921
Email developer.services@thameswater.co.uk

NB ✓
SL

06 December 2017

Dear Mr Bradford

**Notice of consent to connect to a public sewer/public lateral drain under
Section 106 of the Water Industry Act 1991**

Site Address: 10 Worton Drive, Reading, Berkshire, RG2 0TG

Thank you for sending us your sewer connection application for the above address.

We're pleased to let you know that your application has received our conditional consent for the proposed connection(s) to the public sewer.

This does not guarantee capacity exists within our network and is given for the legal right of communication with the public sewer only in accordance with the description below. For capacity based enquiries and capacity checks within our network please make a Pre Development Enquiry application. Applications can be made on the Thames Water website. If you have already received approval for a pre-development enquiry then no further action is required in regards to capacity checks.

This consent does not infer any right to enter or cross third party land and must not be used for the discharge of any drainage related planning conditions.

You will be responsible for obtaining any necessary licenses and or permission from the Highway Authority, Planning Authority and or third party land owners

The connection to our sewer will need to be inspected by us before the trench is backfilled. We require at least five working days' notice before the connection works begin to ensure we can attend site. You can arrange our attendance by calling 0800 009 3921.

Please make sure that this Notice is to be available on site for inspection during the course of these works.

Our consent is subject to the conditions laid out in the enclosed Conditions of Consent.

Thames Water
Developer Services
1st Floor West
Clearwater Court
Vastern Road
Reading
RG1 8DB

T 0800 009 3921
I www.thameswater.co.uk

Thames Water Utilities Ltd
Registered in England and Wales
No. 2366661, Registered office



Conditions of Consent

1. This consent is subject to conditions that may be imposed through the planning process
2. An infrastructure charge will be payable as a result of connecting a property to the Public Sewerage System for the first time for domestic purposes by virtue of Section 146(2)b of the Water Industry Act 1991. We will invoice this charge separately if applicable.
3. A demarcation chamber must be constructed on the lateral drain at the property boundary, or as near to the property boundary as possible. When the connection has been completed satisfactorily, the chamber will become the responsibility of Thames Water, and will mark the end of the adopted pipework. The remainder of the drain, usually the part of the drain within the property boundary will be your responsibility.
4. Demarcation chambers to form part of the adoptable lateral drain should be constructed of either pre-cast concrete or brick and should be a minimum of 450mm in diameter for 100mm diameter foul water sewers and 150mm diameter surface water sewers.
5. The use of plastic pipes will not be permitted within the public sewer or lateral drain, unless the plastic pipe can withstand 4000 psi jetting pressure.
6. It is your responsibility to check that the invert levels of the main sewer/connection are compatible.
7. All works shall comply with the requirements of 'Sewers for Adoption' 6th edition.
8. Confined space entry procedures must be observed when breaking into the existing public sewerage system.
9. Connections into manholes must be made with soffits level and must enter "with the flow". Backdrops must be constructed outside the manhole chamber.
10. The exact dimensions of the sewer pipe should be verified on site by careful internal and external measurement prior to cutting the pipe.
11. Junction connections must be made by cutting in a purpose made junction, jointed using 'flexible couplings'. The use of saddles will not normally be permitted.
12. If you appoint a private contractor to carry out the connection works, then it is your responsibility to ensure that the contractor is competent. For hazard information, please see the enclosed 'Third-party connection to sewers'.
13. The connection to our sewer will need to be inspected by us before the trench is backfilled. We require at least five working days' notice before the

Thames Water
Developer Services
1st Floor West
Clearwater Court
Vastern Road
Reading
RG1 8DB

T 0800 009 3921
I www.thameswater.co.uk

Thames Water Utilities Ltd
Registered in England and Wales
No. 2366661, Registered office



Hazard Information

Third-party connection to sewers

Anyone wishing to connect their property to a Thames Water sewer must comply with the requirements of Section 106 of the Water Act 1991, as amended.

Significant Hazards

We strongly recommend that before undertaking work to connect to our sewers, the following significant hazards are considered and, where necessary, addressed.

- Oxygen deficiency
- Toxic gases, fumes or vapours
- Explosion (methane, petrol)
- Flooding
- Physical injury (slips, trips, falls)
- Infections from sewage (Weils disease)

Confined Spaces

Particular care must be taken before entering or working in confined spaces. A confined space is defined as any place in which, by virtue of its enclosed nature, there arises a foreseeable specified risk. A specified risk is a risk of any of the following:

- Serious injury from a fire or explosion;
- Loss of consciousness due to an increase in body temperature;
- Loss of consciousness or asphyxiation arising from gases, etc., or the lack of oxygen;
- Drowning arising from an increase in the level of a liquid.

In addition:

- Before entering any Thames Water asset a competent person must carry out an assessment to determine the need for entry and a safe system of work to be applied.
- Children and young persons must not enter the work-space.
- After the sewer connection work, it is important to wash before eating, smoking or treating cuts and abrasions. Avoiding infection depends upon strict personal hygiene and effective care of cuts and abrasions.

Thames Water
Developer Services
1st Floor West
Clearwater Court
Vastern Road
Reading
RG1 8DB

T 0800 009 3921
I www.thameswater.co.uk

Thames Water Utilities Ltd
Registered in England and Wales
No. 2366661, Registered office