



LAB UK Limited

34 Britannia Court Burnt Mills Industrial Estate Basildon Essex SS13 1EU

Tel 08447 703 349 – Fax 01268 726 143

Email technical@labukltd.co.uk



CLIENT DETAILS

FAO: Inspection Division
Aspect Contracts Ltd (Inspection)
Aspect House
Honeywood Road
Basildon
Essex
SS14 3EG

BULK ANALYSIS REPORT

Report No: BK 52078

Job No: 120164
Date Sample Booked in: 20-May-16
Report Confirmation Date: 23-May-16
Order No: GW10125002
Client Reference:
Sample Source: Brought in by Client

Sample(s) of material were examined with a stereo microscope, polarised light and dispersion staining technique as described in the Company's MAAM 04 Document that incorporates methods set out in the HSG 248.

Opinions are not covered by UKAS accreditation. We are not accredited for 'Soil' analysis, we are accredited to analyse elements within soil.

Report For : - 79 London Road Flat A Reading RG1 5BY

Samples analysed on 23 May 2016

Sample No	Sample Location/Description	Material Type (See # Note)	Asbestos Fibre Type	Bag Sample Size:
52078-1	01 - Bed - Ceiling	Textured Coating	Chrysotile	

Site Comments:

Analysts Signature and Reported by: Chris Hall (Quality Manager)