

Cellular Storage Details

Infil Coef - Base (m/hr) 0.036000 Porosity 0.95
 Infil Coef - Sides (m/hr) 0.036000 Invert Level (m) 0.000
 Safety Factor 2.0 Ground Level (m) 0.400

Depth (m)	Area (m ²)	Infil. Area (m ²)	Depth (m)	Area (m ²)	Infil. Area (m ²)	Depth (m)	Area (m ²)	Infil. Area (m ²)	Depth (m)	Area (m ²)	Infil. Area (m ²)
0.00	22.5	22.5	0.70	0.0	30.1	1.40	0.0	30.1	2.10	0.0	30.1
0.10	22.5	24.4	0.80	0.0	30.1	1.50	0.0	30.1	2.20	0.0	30.1
0.20	22.5	26.3	0.90	0.0	30.1	1.60	0.0	30.1	2.30	0.0	30.1
0.30	22.5	28.2	1.00	0.0	30.1	1.70	0.0	30.1	2.40	0.0	30.1
0.40	22.5	30.1	1.10	0.0	30.1	1.80	0.0	30.1	2.50	0.0	30.1
0.50	0.0	30.1	1.20	0.0	30.1	1.90	0.0	30.1			
0.60	0.0	30.1	1.30	0.0	30.1	2.00	0.0	30.1			

Note:

Infiltration Rate = 1×10^{-5} m/s

Area = 4.5m x 5.0m x 0.4m deep

Peter Brett Associates LLP		Page 2
Caversham Bridge House Waterman Place Reading RG1 8DN	Green Park Village Cellular Soakaway North 2	
Date 01 July 2010 File north 2.SRC	Designed By VH Checked By	
Micro Drainage	Source Control W.11.4 net	

Rainfall Details

Region	ENG+WAL	Cv (Summer)	0.750	Summer Storms	Yes
Return Period (years)	30	Cv (Winter)	0.840	Winter Storms	Yes
M5-60 (mm)	18.600	Shortest Storm (mins)	15	Climate Change %	+0
Ratio-R	0.400	Longest Storm (mins)	10080		

Time / Area Diagram

Total Area (ha) = 0.017

Time from:	(mins) to:	Area (ha)
0	4	0.017

Summary of Results for 10 year Return Period

Half Drain Time : 227 minutes

Storm Duration (mins)	Maximum Filtration (l/s)	Maximum Outflow (l/s)	Maximum Water Level (m OD)	Maximum Depth (m)	Maximum Volume (m³)	Status
15 Summer	0.1	0.1	0.0793	0.0793	1.7	0 K
30 Summer	0.1	0.1	0.1003	0.1003	2.1	0 K
60 Summer	0.1	0.1	0.1188	0.1188	2.5	0 K
120 Summer	0.1	0.1	0.1323	0.1323	2.8	0 K
180 Summer	0.1	0.1	0.1358	0.1358	2.9	0 K
240 Summer	0.1	0.1	0.1363	0.1363	2.9	0 K
360 Summer	0.1	0.1	0.1348	0.1348	2.9	0 K
480 Summer	0.1	0.1	0.1318	0.1318	2.8	0 K
600 Summer	0.1	0.1	0.1278	0.1278	2.7	0 K
720 Summer	0.1	0.1	0.1233	0.1233	2.6	0 K
960 Summer	0.1	0.1	0.1143	0.1143	2.4	0 K
1440 Summer	0.1	0.1	0.0968	0.0968	2.1	0 K
2160 Summer	0.1	0.1	0.0748	0.0748	1.6	0 K
2880 Summer	0.1	0.1	0.0593	0.0593	1.3	0 K
4320 Summer	0.1	0.1	0.0447	0.0447	1.0	0 K
5760 Summer	0.1	0.1	0.0372	0.0372	0.8	0 K
7200 Summer	0.1	0.1	0.0322	0.0322	0.7	0 K
8640 Summer	0.1	0.1	0.0287	0.0287	0.6	0 K
10080 Summer	0.1	0.1	0.0257	0.0257	0.5	0 K
15 Winter	0.1	0.1	0.0893	0.0893	1.9	0 K
30 Winter	0.1	0.1	0.1128	0.1128	2.4	0 K
60 Winter	0.1	0.1	0.1343	0.1343	2.9	0 K
120 Winter	0.1	0.1	0.1512	0.1512	3.2	0 K
180 Winter	0.1	0.1	0.1557	0.1557	3.3	0 K
240 Winter	0.1	0.1	0.1562	0.1562	3.3	0 K
360 Winter	0.1	0.1	0.1533	0.1533	3.3	0 K
480 Winter	0.1	0.1	0.1483	0.1483	3.2	0 K
600 Winter	0.1	0.1	0.1418	0.1418	3.0	0 K
720 Winter	0.1	0.1	0.1353	0.1353	2.9	0 K
960 Winter	0.1	0.1	0.1208	0.1208	2.6	0 K
1440 Winter	0.1	0.1	0.0938	0.0938	2.0	0 K

Storm Duration (mins)	Rain (mm/hr)	Time-Peak (mins)
-----------------------	--------------	------------------

Note:

1 in 10 year water level below invert of incoming pipe

15 Summer	55.64	18
30 Summer	35.95	33
60 Summer	22.31	62
120 Summer	13.50	120
180 Summer	9.99	170
240 Summer	8.04	198
360 Summer	5.91	260
480 Summer	4.75	328
600 Summer	4.00	398
720 Summer	3.48	464
960 Summer	2.79	600
1440 Summer	2.04	864
2160 Summer	1.50	1232
2880 Summer	1.20	1560
4320 Summer	0.88	2248
5760 Summer	0.70	2992
7200 Summer	0.59	3680
8640 Summer	0.51	4408
10080 Summer	0.45	5144
15 Winter	55.64	18
30 Winter	35.95	32
60 Winter	22.31	62
120 Winter	13.50	118
180 Winter	9.99	174
240 Winter	8.04	226
360 Winter	5.91	280
480 Winter	4.75	358
600 Winter	4.00	434
720 Winter	3.48	506
960 Winter	2.79	648
1440 Winter	2.04	910

Peter Brett Associates LLP		Page 4
Caversham Bridge House Waterman Place Reading RG1 8DN	Green Park Village Cellular Soakaway North 2	
Date 01 July 2010 File north 2.SRC	Designed By VH Checked By	
Micro Drainage	Source Control W.11.4 net	

Summary of Results for 10 year Return Period

Storm Duration (mins)	Maximum Filtration (l/s)	Maximum Outflow (l/s)	Maximum Water Level (m OD)	Maximum Depth (m)	Maximum Volume (m ³)	Status
2160 Winter	0.1	0.1	0.0623	0.0623	1.3	0 K
2880 Winter	0.1	0.1	0.0472	0.0472	1.0	0 K
4320 Winter	0.1	0.1	0.0357	0.0357	0.8	0 K
5760 Winter	0.1	0.1	0.0292	0.0292	0.6	0 K
7200 Winter	0.1	0.1	0.0247	0.0247	0.5	0 K
8640 Winter	0.1	0.1	0.0217	0.0217	0.5	0 K
10080 Winter	0.0	0.0	0.0192	0.0192	0.4	0 K

Storm Duration (mins)	Rain (mm/hr)	Time-Peak (mins)
2160 Winter	1.50	1256
2880 Winter	1.20	1560
4320 Winter	0.88	2292
5760 Winter	0.70	3000
7200 Winter	0.59	3744
8640 Winter	0.51	4408
10080 Winter	0.45	5152

Peter Brett Associates LLP		Page 5
Caversham Bridge House Waterman Place Reading RG1 8DN	Green Park Village Cellular Soakaway North 2	
Date 01 July 2010 File north 2.SRC	Designed By VH Checked By	
Micro Drainage	Source Control W.11.4 net	

Summary of Results for 30 year Return Period

Half Drain Time : 309 minutes

Storm Duration (mins)	Maximum Filtration (l/s)	Maximum Outflow (l/s)	Maximum Water Level (m OD)	Maximum Depth (m)	Maximum Volume (m³)	Status
15 Summer	0.1	0.1	0.1013	0.1013	2.2	0 K
30 Summer	0.1	0.1	0.1293	0.1293	2.8	0 K
60 Summer	0.1	0.1	0.1552	0.1552	3.3	0 K
120 Summer	0.1	0.1	0.1757	0.1757	3.8	0 K
180 Summer	0.1	0.1	0.1827	0.1827	3.9	0 K
240 Summer	0.1	0.1	0.1832	0.1832	3.9	0 K
360 Summer	0.1	0.1	0.1812	0.1812	3.9	0 K
480 Summer	0.1	0.1	0.1777	0.1777	3.8	0 K
600 Summer	0.1	0.1	0.1732	0.1732	3.7	0 K
720 Summer	0.1	0.1	0.1682	0.1682	3.6	0 K
960 Summer	0.1	0.1	0.1577	0.1577	3.4	0 K
1440 Summer	0.1	0.1	0.1368	0.1368	2.9	0 K
2160 Summer	0.1	0.1	0.1088	0.1088	2.3	0 K
2880 Summer	0.1	0.1	0.0868	0.0868	1.9	0 K
4320 Summer	0.1	0.1	0.0573	0.0573	1.2	0 K
5760 Summer	0.1	0.1	0.0452	0.0452	1.0	0 K
7200 Summer	0.1	0.1	0.0392	0.0392	0.8	0 K
8640 Summer	0.1	0.1	0.0347	0.0347	0.7	0 K
10080 Summer	0.1	0.1	0.0312	0.0312	0.7	0 K
15 Winter	0.1	0.1	0.1138	0.1138	2.4	0 K
30 Winter	0.1	0.1	0.1452	0.1452	3.1	0 K
60 Winter	0.1	0.1	0.1752	0.1752	3.8	0 K
120 Winter	0.1	0.1	0.2002	0.2002	4.3	FLOOD RISK
180 Winter	0.1	0.1	0.2092	0.2092	4.5	FLOOD RISK
240 Winter	0.1	0.1	0.2112	0.2112	4.5	FLOOD RISK
360 Winter	0.1	0.1	0.2072	0.2072	4.4	FLOOD RISK
480 Winter	0.1	0.1	0.2022	0.2022	4.3	FLOOD RISK
600 Winter	0.1	0.1	0.1957	0.1957	4.2	0 K
720 Winter	0.1	0.1	0.1882	0.1882	4.0	0 K
960 Winter	0.1	0.1	0.1722	0.1722	3.7	0 K
1440 Winter	0.1	0.1	0.1408	0.1408	3.0	0 K

Storm Duration (mins)	Rain (mm/hr)	Time-Peak (mins)
15 Summer	70.41	18
30 Summer	45.87	33
60 Summer	28.61	62
120 Summer	17.34	122
180 Summer	12.81	180
240 Summer	10.29	224
360 Summer	7.52	282
480 Summer	6.02	346
600 Summer	5.06	414
720 Summer	4.39	484
960 Summer	3.51	618
1440 Summer	2.55	882
2160 Summer	1.86	1272
2880 Summer	1.48	1616
4320 Summer	1.07	2292
5760 Summer	0.86	2992
7200 Summer	0.72	3680
8640 Summer	0.62	4416
10080 Summer	0.55	5144
15 Winter	70.41	18
30 Winter	45.87	33
60 Winter	28.61	62
120 Winter	17.34	120
180 Winter	12.81	176
240 Winter	10.29	230
360 Winter	7.52	324
480 Winter	6.02	372
600 Winter	5.06	448
720 Winter	4.39	526
960 Winter	3.51	674
1440 Winter	2.55	952

Peter Brett Associates LLP		Page 6
Caversham Bridge House Waterman Place Reading RG1 8DN	Green Park Village Cellular Soakaway North 2	
Date 01 July 2010 File north 2.SRC	Designed By VH Checked By	
Micro Drainage	Source Control W.11.4 net	

Summary of Results for 30 year Return Period

Storm Duration (mins)	Maximum Filtration (l/s)	Maximum Outflow (l/s)	Maximum Water Level (m OD)	Maximum Depth (m)	Maximum Volume (m ³)	Status
2160 Winter	0.1	0.1	0.0993	0.0993	2.1	0 K
2880 Winter	0.1	0.1	0.0683	0.0683	1.5	0 K
4320 Winter	0.1	0.1	0.0442	0.0442	0.9	0 K
5760 Winter	0.1	0.1	0.0357	0.0357	0.8	0 K
7200 Winter	0.1	0.1	0.0302	0.0302	0.6	0 K
8640 Winter	0.1	0.1	0.0262	0.0262	0.6	0 K
10080 Winter	0.1	0.1	0.0232	0.0232	0.5	0 K

Storm Duration (mins)	Rain (mm/hr)	Time-Peak (mins)
2160 Winter	1.86	1340
2880 Winter	1.48	1672
4320 Winter	1.07	2288
5760 Winter	0.86	3000
7200 Winter	0.72	3688
8640 Winter	0.62	4416
10080 Winter	0.55	5144

Peter Brett Associates LLP		Page 7
Caversham Bridge House Waterman Place Reading RG1 8DN	Green Park Village Cellular Soakaway North 2	
Date 01 July 2010 File north 2.SRC	Designed By VH Checked By	
Micro Drainage	Source Control W.11.4 net	

Summary of Results for 100 year Return Period (+30%)

Half Drain Time : 514 minutes

Storm Duration (mins)	Maximum Filtration (l/s)	Maximum Outflow (l/s)	Maximum Water Level (m OD)	Maximum Depth (m)	Maximum Volume (m³)	Status
15 Summer	0.1	0.1	0.1722	0.1722	3.7	0 K
30 Summer	0.1	0.1	0.2232	0.2232	4.8	FLOOD RISK
60 Summer	0.1	0.1	0.2732	0.2732	5.8	FLOOD RISK
120 Summer	0.1	0.1	0.3172	0.3172	6.8	FLOOD RISK
180 Summer	0.1	0.1	0.3357	0.3357	7.2	FLOOD RISK
240 Summer	0.1	0.1	0.3437	0.3437	7.4	FLOOD RISK
360 Summer	0.1	0.1	0.3437	0.3437	7.4	FLOOD RISK
480 Summer	0.1	0.1	0.3392	0.3392	7.2	FLOOD RISK
600 Summer	0.1	0.1	0.3332	0.3332	7.1	FLOOD RISK
720 Summer	0.1	0.1	0.3272	0.3272	7.0	FLOOD RISK
960 Summer	0.1	0.1	0.3137	0.3137	6.7	FLOOD RISK
1440 Summer	0.1	0.1	0.2867	0.2867	6.1	FLOOD RISK
2160 Summer	0.1	0.1	0.2482	0.2482	5.3	FLOOD RISK
2880 Summer	0.1	0.1	0.2137	0.2137	4.6	FLOOD RISK
4320 Summer	0.1	0.1	0.1563	0.1563	3.3	0 K
5760 Summer	0.1	0.1	0.1123	0.1123	2.4	0 K
7200 Summer	0.1	0.1	0.0808	0.0808	1.7	0 K
8640 Summer	0.1	0.1	0.0603	0.0603	1.3	0 K
10080 Summer	0.1	0.1	0.0492	0.0492	1.1	0 K
15 Winter	0.1	0.1	0.1932	0.1932	4.1	0 K
30 Winter	0.1	0.1	0.2512	0.2512	5.4	FLOOD RISK
60 Winter	0.1	0.1	0.3082	0.3082	6.6	FLOOD RISK
120 Winter	0.1	0.1	0.3592	0.3592	7.7	FLOOD RISK
180 Winter	0.1	0.1	0.3822	0.3822	8.2	FLOOD RISK
240 Winter	0.1	0.1	0.3927	0.3927	8.4	FLOOD RISK
360 Winter	0.2	0.2	0.3972	0.3972	8.5	FLOOD RISK
480 Winter	0.1	0.1	0.3927	0.3927	8.4	FLOOD RISK
600 Winter	0.1	0.1	0.3842	0.3842	8.2	FLOOD RISK
720 Winter	0.1	0.1	0.3762	0.3762	8.0	FLOOD RISK
960 Winter	0.1	0.1	0.3592	0.3592	7.7	FLOOD RISK
1440 Winter	0.1	0.1	0.3202	0.3202	6.8	FLOOD RISK

Storm Duration (mins)	Rain (mm/hr)	Time-Peak (mins)
15 Summer	118.47	19
30 Summer	77.88	33
60 Summer	48.84	64
120 Summer	29.64	122
180 Summer	21.86	182
240 Summer	17.52	242
360 Summer	12.72	360
480 Summer	10.14	410
600 Summer	8.50	474
720 Summer	7.36	534
960 Summer	5.85	666
1440 Summer	4.23	938
2160 Summer	3.06	1344
2880 Summer	2.42	1732
4320 Summer	1.75	2504
5760 Summer	1.38	3176
7200 Summer	1.15	3888
8640 Summer	0.99	4504
10080 Summer	0.87	5144
15 Winter	118.47	19
30 Winter	77.88	33
60 Winter	48.84	62
120 Winter	29.64	120
180 Winter	21.86	178
240 Winter	17.52	236
360 Winter	12.72	348
480 Winter	10.14	454
600 Winter	8.50	542
720 Winter	7.36	568
960 Winter	5.85	722
1440 Winter	4.23	1024

Summary of Results for 100 year Return Period (+30%)

Storm Duration (mins)	Maximum Filtration (l/s)	Maximum Outflow (l/s)	Maximum Water Level (m OD)	Maximum Depth (m)	Maximum Volume (m³)	Status
2160 Winter	0.1	0.1	0.2632	0.2632	5.6	FLOOD RISK
2880 Winter	0.1	0.1	0.2122	0.2122	4.5	FLOOD RISK
4320 Winter	0.1	0.1	0.1303	0.1303	2.8	0 K
5760 Winter	0.1	0.1	0.0733	0.0733	1.6	0 K
7200 Winter	0.1	0.1	0.0482	0.0482	1.0	0 K
8640 Winter	0.1	0.1	0.0417	0.0417	0.9	0 K
10080 Winter	0.1	0.1	0.0372	0.0372	0.8	0 K

Storm Duration (mins)	Rain (mm/hr)	Time-Peak (mins)
2160 Winter	3.06	1452
2880 Winter	2.42	1872
4320 Winter	1.75	2596
5760 Winter	1.38	3232
7200 Winter	1.15	3744
8640 Winter	0.99	4488
10080 Winter	0.87	5144