

DO NOT SCALE

NOTES

IF THIS DRAWING HAS BEEN RECEIVED ELECTRONICALLY IT IS THE PROPRIETORS RESPONSIBILITY TO PRINT THE DOCUMENT TO THE CORRECT SCALE.

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS STATED OTHERWISE IT IS RECOMMENDED THAT INFORMATION IS NOT SCALED OFF THIS DRAWING.

THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS AND SPECIFICATIONS FORMING THE EXTENT OF THIS WORKS PACKAGE.

CROSS REFERENCE SHOULD BE MADE TO ARCHITECTS & STRUCTURAL ENGINEERING DRAWINGS WHERE APPLICABLE.

THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE ARCHITECTS FIRE STRATEGY DRAWING FOR COMPARTMENTATION WHERE APPLICABLE.

NOTES

1. EMERGENCY LIGHTING ILLUMINANCE LEVELS (LUX) SHOWN ARE THE MINIMUM REQUIRED IN ACCORDANCE WITH BS 5266.
2. ANY AREA'S GREATER THAN 60m² ARE TO ACHIEVE A MINIMUM OF 0.5 LUX AT THE WORKING PLANE.
3. ANY MANUAL CALL POINTS/ALARM PANELS AND FIREFIGHTING EQUIPMENT MUST HAVE A MINIMUM VERTICAL ILLUMINANCE OF 5 LUX.
4. EMERGENCY LIGHTING DESIGNS TO BE BASED ON THORLUX LIGHTING PRODUCT RANGES EXCEPT THE TRUST'S INSTRUCTS OTHERWISE.

LEGEND

- 50 LUX
- 1 LUX
- 15 LUX
- 5 LUX

PO1	MAY 24	ISSUED FOR COMMENTS	FB
REV	DATE	DESCRIPTION	ISSUED BY

ISSUED FOR STAGE 2 S2

SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION

READERS OF THIS DRAWING:
ALL EFFORTS HAVE BEEN TAKEN BY DSSR TO DESIGN OUT SIGNIFICANT HAZARDS WITHIN THE DESIGN RISK ASSESSMENT PROCESS. IT IS OUR OPINION THAT THE HAZARDS DETAILED BELOW CANNOT BE DESIGNED OUT BY US GIVEN THE CONSTRAINTS OF THE BRIEF AND ARE HIGHLIGHTED SO THAT OTHER MEANS CAN BE DEVELOPED TO MITIGATE THE RESIDUAL RISKS IDENTIFIED.

IT IS ASSUMED THAT A COMPETENT M&E CONTRACTOR OR USER WILL BE AWARE OF THE STANDARD FORESEEABLE RISKS ASSOCIATED WITH WORKING WITH THE TYPE OF SERVICES DETAILED WITHIN THE DRAWING.

DSSR CONSULTING ENGINEERS

Glasgow Harrogate London Manchester

Manchester Office
Trafalgar House
Chester Road
Salford
Manchester
M32 6RS

Tel: +44 (0)161 872 4811
manchester@dssr.co.uk
www.dssr.co.uk

MTX CONSULTING LTD
Trafalgar House
Brook Court
Lower Market Road
Harrogate
West Yorkshire
HG1 1PU

Tel: 0181 694 9125
info@mtx.co.uk
www.mtx.co.uk

PROJECT:
Royal Berkshire Hospital
NHS Foundation Trust
Royal Berkshire Hospital Urology

TITLE:
EMERGENCY LIGHTING STRATEGY
LEVEL 00

Drawn By	FB	Checked By	BH	DSSR Ref	M3364
Date	MAY 24	Date	AD	Scale & Notes	1:50

DRAWING No:
P24-0002-DSSR-XX-00-DR-E-63110

Project - Originator - Volume - Level - Type - Role - Number
P24-0002-DSSR-XX-00-DR-E-63110

REV:
P01