

NOTES

IF THIS DRAWING HAS BEEN RECEIVED ELECTRONICALLY IT IS THE RECIPIENT'S RESPONSIBILITY TO PRINT THE DOCUMENT TO THE CORRECT SCALE.

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS STATED OTHERWISE IT IS RECOMMENDED THAT INFORMATION IS NOT SCALED OFF THIS DRAWING.

THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS AND SPECIFICATIONS FORMING THE EXTENT OF THIS WORK PACKAGE.

CROSS REFERENCE SHOULD BE MADE TO ARCHITECTS & STRUCTURAL ENGINEERING DRAWINGS WHERE APPLICABLE.

THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE ARCHITECTS FIRE STRATEGY DRAWING FOR COMPARTMENTATION WHERE APPLICABLE.

LEGEND

- EXTERNAL CCTV CAMERA, HIGH DEFINITION, IP65 MINIMUM.
- INTERNAL CCTV CAMERA.
- ACCESS CONTROL – CARD READER, REQUEST TO EXIT BUTTON, GREEN MANUAL BREAK GLASS MAGNETIC LOCK.
- ACCESS CONTROL – GREEN MANUAL BREAK GLASS MAGNETIC LOCK.
- DOOR CONTACTS – INTRUDER ALARM.
- DUAL TECH DETECTOR – INTRUDER ALARM.
- INTRUDER ALARM PANEL.
- VIDEO INTERCOM.

NOTES

- THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH DSSR MECHANICAL SERVICES LAYOUTS AND ARCHITECTURAL LAYOUTS.
- PROVISIONS INDICATED AND SECURITY EQUIPMENT MANUFACTURER ARE STILL SUBJECT TO CONFIRMATION OF THE TRUST'S PREFERRED SECURITY STRATEGY AND CHOICE.
- POSSIBILITY OF LOCATING THE SECURITY EQUIPMENT RACK WITHIN THE IT HUB/COMMS ROOM TO BE CONFIRMED WITH THE TRUST'S IT TEAM.
- DO NOT SCALE FROM THIS DRAWING.
- ELECTRICAL INSTALLATION SHALL BE IN ACCORDANCE WITH BS 7671, THE 18TH EDITION WIRING REGULATIONS AND ALL RELEVANT HTM DOCUMENTS.

FOI	MAY 24	ISSUED FOR COMMENTS	FB
REV	DATE	DESCRIPTION	ISSUED BY

ISSUED FOR STAGE 2 S2

SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION

READERS OF THIS DRAWING:

ALL EFFORTS HAVE BEEN TAKEN BY DSSR TO DESIGN OUT SIGNIFICANT HAZARDS WITHIN THE DESIGN RISK ASSESSMENT PROCESS. IT IS OUR OPINION THAT THE HAZARDS DETAILED BELOW CANNOT BE DESIGNED OUT BY US GIVEN THE CONSTRAINTS OF THE BRIEF AND ARE HIGHLIGHTED SO THAT OTHER MEANS CAN BE DEVELOPED TO MITIGATE THE RESIDUAL RISKS IDENTIFIED.

IT IS ASSUMED THAT A COMPETENT M&E CONTRACTOR OR USER WILL BE AWARE OF THE STANDARD FORESEEABLE RISKS ASSOCIATED WITH WORKING WITH THE TYPE OF SERVICES DETAILED WITHIN THE DRAWING.

DSSR CONSULTING ENGINEERS

Glasgow Harrogate London Manchester

Manchester Office
Trafalgar House
Chester Road
Buryfield
Manchester
M20 0RS

Tel: +44 (0)161 872 4811
manchester@dssr.co.uk
www.dssr.co.uk

MTX CONSULTING LTD

Brookside House
Lower Macclesfield Road
Macclesfield
Cheshire
SK10 2DQ

T: 0161 894 9125
info@mtx.co.uk
www.mtx.co.uk

PROJECT:

Royal Berkshire Hospital
NHS Foundation Trust
Royal Berkshire Hospital Urology

TITLE:

SECURITY STRATEGY
LEVEL 00

Drawn By	FB	Checked By	BH	DSSR Ref	M3364
Date	MAY 24	Scale & Velocity	AO	1:50	

DRAWING No.	Project - Originator - Volume - Level - Type - Role - Number	REV
P24-0002-DSSR-XX-00-DR-E-68100		P01

THIS DRAWING IS THE PROPERTY OF DSSR

COVERED
WALKWAY LINK TO
MAIN HOSPITAL

