DO NOT SCALE

NOTES

IF THIS DRAWING HAS BEEN RECEIVED ELECTRONICALLY IT IS THE RECIPIENTS RESPONSIBILITY TO PRINT THE DOCUMENT TO THE CORRECT SCALE.

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS STATED OTHERWISE IT IS RECOMMENDED THAT INFORMATION IS NOT SCALED OFF THIS DRAWING.

THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS AND SPECIFICATIONS FORMING THE EXTENT OF THIS WORKS PACKAGE.

CROSS REFERENCE SHOULD BE MADE TO ARCHITECTS & STRUCTURAL ENGINEERING DRAWINGS WHERE APPLICABLE.

THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE ARCHITECTS FIRE STRATEGY DRAWING FOR COMPARTMENTATION WHERE APPLICABLE.

NOTES

1. LIGHTING LEVELS, CRI AND UNIFORMITY ARE TO BE IN LINE WITH CIBSE LIGHTING GUIDE LG2 : 2019.
2. LIGHTING LEVELS EXCLUDE THOSE TO BE ACHIEVED BY EXAM LAMPS.
3. LIGHTING CONTROL METHODS ARE GENERALLY IN ACCORDANCE WITH THE RECOMMENDATIONS IN CIBSE LIGHTING GUIDE LG2 : 2019.
4. GENERAL LIGHTING DESIGNS TO BE BASED ON THORLUX LIGHTING PRODUCT RANGES UNLESS TRUST DIRECTS OTHERWISE.

LEGEND

- MANUAL ON/OFF SWITCHING
- AUTOMATIC PRESENCE DETECTION
- MANUAL ON WITH AUTOMATIC ABSENCE DETECTION
- MANUAL DIMMING
- SKY CEILING C/W DIMMING

CAUSE AND EFFECT

MANUAL ON/OFF SWITCH
- MANUALLY SWITCHED ON AND OFF

PRESENCE DETECTION
- AUTOMATICALLY SWITCHED ON WHEN OCCUPANCY IS SENSED.
- AUTOMATICALLY SWITCHED OFF AFTER A SET TIME WHEN OCCUPANCY IS NOT SENSED.
- VARIABLE OFF TIME FROM 5 SECONDS TO 4 HOURS

ABSENCE DETECTION
- MANUALLY SWITCHED ON AND OFF
- AUTOMATICALLY SWITCHED OFF AFTER A SET TIME WHEN OCCUPANCY IS NOT SENSED.
- VARIABLE OFF TIME FROM 5 SECONDS TO 4 HOURS

REV.	DATE	DESCRIPTION	ISSUED BY
P01	MAY 24	ISSUED FOR COMMENTS	FB

Drawing Status: ISSUED FOR STAGE 2 — S2

SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION

READERS OF THIS DRAWING:
ALL EFFORTS HAVE BEEN TAKEN BY DSSR TO DESIGN OUT SIGNIFICANT HAZARDS WITHIN THE DESIGN RISK ASSESSMENT PROCESS. IT IS OUR OPINION THAT THE HAZARDS DETAILED BELOW CANNOT BE DESIGNED OUT BY US GIVEN THE CONSTRAINTS OF THE BRIEF AND ARE HIGHLIGHTED SO THAT OTHER MEANS CAN BE DEVELOPED TO MITIGATE THE RESIDUAL RISKS IDENTIFIED.

IT IS ASSUMED THAT A COMPETENT M&E CONTRACTOR OR USER WILL BE AWARE OF THE STANDARD FORESEEABLE RISKS ASSOCIATED WITH WORKING WITH THE TYPE OF SERVICES DETAILED WITHIN THE DRAWING.

DSSR | CONSULTING ENGINEERS
Glasgow Harrogate London Manchester

Manchester Office
Trafford House
Chester Road
Stretford
Manchester
M32 0RS

Tel: +44 (0)161 872 4811
manchester@dssr.co.uk
www.dssr.co.uk

MTX Contracts LTD
Innovation House
Brooke Court
Lower Meadow Road
Handforth
Wilmslow
SK9 3ND

T: 0161 694 0123
info@mtxcontracts.co.uk
www.mtxcontracts.co.uk

PROJECT:
Royal Berkshire Hospital
NHS Foundation Trust
Royal Berkshire Hospital Urology

TITLE:
LIGHTING CONTROL STRATEGY
LEVEL 00

Designed By	Checked By	DSSR Ref
FB	BH	M5364
Drawn By: FB	Date: MAY 24	Size & Scale(s): A0 1:50

Project - Originator - Volume - Level - Type - Role - Number
DRAWING No: P24-0002-DSSR-XX-00-DR-E-63100
REV: P01

© This drawing is the copyright of DSSR