

Property & room attributes					Daylight/Sunlight (BRE 2011)							
Floor	Flat/Unit no.	Room ref.	Property type	Room use	ADF		NSL (% room)	Room depth criterion		APSH room		
					Target (%)	ADF (%)		Limit (current) (m)	Criterio n met?	Annual (%)	Winter (%)	
B1												
F01	Plan(s)	R1	Residential	Bedroom	1.0	0.38	39%	9.71	Yes	2	1	
	Plan(s)	R2	Residential	LKD	1.5	1.34	36%	Exempt: Dual Aspec	Yes	8	4	
	Plan(s)	R3	Residential	Bedroom	1.0	1.24	27%	8.97	Yes	5	2	
	Plan(s)	R4	Residential	Bedroom	1.0	0.48	38%	9.71	Yes	1	1	
	Plan(s)	R5	Residential	LKD	1.5	5.59	99%	Exempt: Dual Aspec	Yes	60	19	
	Plan(s)	R6	Residential	Bedroom	1.0	3.22	96%	11.20	Yes	44	13	
	Plan(s)	R7	Residential	Bedroom	1.0	1.39	94%	10.77	Yes	13	13	
	Plan(s)	R8	Residential	LKD	1.5	2.11	77%	Exempt: Dual Aspec	Yes	53	19	
	Plan(s)	R9	Residential	Bedroom	1.0	0.85	63%	10.10	Yes	7	7	
	Plan(s)	R10	Residential	LKD	1.5	1.42	73%	Exempt: Dual Aspec	Yes	49	17	
	Plan(s)	R11	Residential	LKD	1.5	1.10	97%	10.08	Yes	9	9	
	Plan(s)	R12	Residential	Bedroom	1.0	2.74	81%	11.27	Yes	0	0	
	Plan(s)	R13	Residential	Bedroom	1.0	1.62	53%	10.14	Yes	0	0	
	Plan(s)	R14	Residential	Studio	1.5	0.90	42%	Exempt: Dual Aspec	Yes	0	0	
	Plan(s)	R15	Residential	LKD	1.5	0.71	29%	10.47	Yes	2	0	
	Plan(s)	R16	Residential	Bedroom	1.0	1.85	61%	9.70	Yes	4	0	
	Plan(s)	R17	Residential	Bedroom	1.0	1.83	61%	9.50	Yes	7	0	
	Plan(s)	R18	Residential	LKD	1.5	0.61	24%	10.34	Yes	2	0	
	Plan(s)	R19	Residential	Bedroom	1.0	0.99	43%	9.60	Yes	6	0	
	Plan(s)	R20	Residential	Bedroom	1.0	1.22	79%	10.07	Yes	17	4	
	Plan(s)	R21	Residential	LKD	1.5	2.45	89%	Exempt: Dual Aspec	Yes	30	5	
	Plan(s)	R22	Residential	Studio	1.5	1.12	76%	Exempt: Dual Aspec	Yes	7	5	
	Plan(s)	R23	Residential	Bedroom	1.0	1.90	72%	Exempt: Dual Aspec	Yes	0	0	
	Plan(s)	R24	Residential	LKD	1.5	0.99	66%	Exempt: Dual Aspec	Yes	1	0	
	Plan(s)	R25	Residential	Bedroom	1.0	0.04	1%	11.65	Yes	0	0	
F02	Plan(s)	R1	Residential	Studio	1.5	1.54	71%	Exempt: Dual Aspec	Yes	12	0	
	Plan(s)	R2	Residential	Bedroom	1.0	0.41	57%	9.83	Yes	1	0	
	Plan(s)	R3	Residential	LKD	1.5	1.79	68%	Exempt: Dual Aspec	Yes	19	0	
	Plan(s)	R4	Residential	Bedroom	1.0	1.72	94%	9.41	Yes	13	0	
	Plan(s)	R5	Residential	Bedroom	1.0	0.71	56%	Exempt: Dual Aspec	Yes	0	0	
	Plan(s)	R6	Residential	LKD	1.5	1.75	62%	Exempt: Dual Aspec	Yes	10	0	
	Plan(s)	R7	Residential	Bedroom	1.0	1.52	67%	9.41	Yes	4	0	
	Plan(s)	R8	Residential	Bedroom	1.0	0.75	44%	Exempt: Dual Aspec	Yes	2	1	
	Plan(s)	R9	Residential	LKD	1.5	1.52	36%	Exempt: Dual Aspec	Yes	9	4	
	Plan(s)	R10	Residential	Bedroom	1.0	1.41	30%	9.40	Yes	4	2	
	Plan(s)	R11	Residential	Bedroom	1.0	0.64	39%	9.91	Yes	2	2	
	Plan(s)	R12	Residential	LKD	1.5	6.11	99%	Exempt: Dual Aspec	Yes	76	29	
	Plan(s)	R13	Residential	Bedroom	1.0	3.54	96%	11.20	Yes	51	20	
	Plan(s)	R14	Residential	Bedroom	1.0	1.66	97%	10.76	Yes	17	17	
	Plan(s)	R15	Residential	LKD	1.5	2.39	86%	Exempt: Dual Aspec	Yes	57	24	
	Plan(s)	R16	Residential	Bedroom	1.0	1.01	75%	10.10	Yes	8	8	
	Plan(s)	R17	Residential	LKD	1.5	1.59	81%	10.80	Yes	50	20	

Property & room attributes					Daylight/Sunlight (BRE 2011)						
Floor	Flat/Unit no.	Room ref.	Property type	Room use	ADF		NSL (% room)	Room depth criterion		APSH room	
					Target (%)	ADF (%)		Limit (current) (m)	Criterion met?	Annual (%)	Winter (%)
	Plan(s)	R18	Residential	LKD	1.5	1.29	99%	10.08	Yes	9	9
	Plan(s)	R19	Residential	Bedroom	1.0	3.00	85%	11.27	Yes	0	0
	Plan(s)	R20	Residential	Bedroom	1.0	1.74	54%	10.14	Yes	0	0
	Plan(s)	R21	Residential	Studio	1.5	1.65	73%	Exempt: Dual Aspect	Yes	5	0
	Plan(s)	R22	Residential	LKD	1.5	0.99	43%	10.47	Yes	3	0
	Plan(s)	R23	Residential	Bedroom	1.0	2.03	69%	9.70	Yes	6	0
	Plan(s)	R24	Residential	Bedroom	1.0	1.95	70%	9.50	Yes	9	0
	Plan(s)	R25	Residential	LKD	1.5	0.88	40%	10.34	Yes	3	0
	Plan(s)	R26	Residential	Bedroom	1.0	1.07	49%	9.60	Yes	5	0
	Plan(s)	R27	Residential	Bedroom	1.0	1.33	86%	10.07	Yes	18	4
	Plan(s)	R28	Residential	LKD	1.5	2.79	91%	Exempt: Dual Aspect	Yes	37	7
	Plan(s)	R29	Residential	Studio	1.5	1.37	85%	Exempt: Dual Aspect	Yes	12	7
	Plan(s)	R30	Residential	Bedroom	1.0	1.99	76%	Exempt: Dual Aspect	Yes	0	0
	Plan(s)	R31	Residential	LKD	1.5	1.11	70%	Exempt: Dual Aspect	Yes	1	0
	Plan(s)	R32	Residential	Bedroom	1.0	0.06	1%	11.65	Yes	0	0
F03	Plan(s)	R1	Residential	Studio	1.5	1.65	86%	Exempt: Dual Aspect	Yes	13	1
	Plan(s)	R2	Residential	Bedroom	1.0	0.70	93%	9.83	Yes	2	1
	Plan(s)	R3	Residential	LKD	1.5	1.95	85%	Exempt: Dual Aspect	Yes	22	0
	Plan(s)	R4	Residential	Bedroom	1.0	1.88	98%	9.41	Yes	16	0
	Plan(s)	R5	Residential	Bedroom	1.0	0.77	89%	Exempt: Dual Aspect	Yes	1	0
	Plan(s)	R6	Residential	LKD	1.5	1.94	77%	Exempt: Dual Aspect	Yes	16	0
	Plan(s)	R7	Residential	Bedroom	1.0	1.73	74%	9.41	Yes	8	0
	Plan(s)	R8	Residential	Bedroom	1.0	0.79	57%	Exempt: Dual Aspect	Yes	3	1
	Plan(s)	R9	Residential	LKD	1.5	1.75	39%	Exempt: Dual Aspect	Yes	12	4
	Plan(s)	R10	Residential	Bedroom	1.0	1.61	33%	9.40	Yes	6	2
	Plan(s)	R11	Residential	Bedroom	1.0	0.76	39%	9.91	Yes	2	2
	Plan(s)	R12	Residential	LKD	1.5	6.65	99%	Exempt: Dual Aspect	Yes	77	30
	Plan(s)	R13	Residential	Bedroom	1.0	3.82	97%	11.20	Yes	57	25
	Plan(s)	R14	Residential	Bedroom	1.0	1.89	97%	10.76	Yes	21	21
	Plan(s)	R15	Residential	LKD	1.5	2.55	98%	Exempt: Dual Aspect	Yes	63	29
	Plan(s)	R16	Residential	Bedroom	1.0	1.12	89%	10.10	Yes	9	9
	Plan(s)	R17	Residential	LKD	1.5	1.69	99%	10.80	Yes	56	24
	Plan(s)	R18	Residential	LKD	1.5	1.38	99%	10.08	Yes	11	11
	Plan(s)	R19	Residential	Bedroom	1.0	3.25	88%	11.27	Yes	0	0
	Plan(s)	R20	Residential	Bedroom	1.0	1.85	56%	10.14	Yes	0	0
	Plan(s)	R21	Residential	Studio	1.5	1.80	83%	Exempt: Dual Aspect	Yes	7	0
	Plan(s)	R22	Residential	LKD	1.5	1.15	53%	10.47	Yes	6	1
	Plan(s)	R23	Residential	Bedroom	1.0	2.15	78%	9.70	Yes	9	1
	Plan(s)	R24	Residential	Bedroom	1.0	2.08	77%	9.50	Yes	10	1
	Plan(s)	R25	Residential	LKD	1.5	1.04	52%	10.34	Yes	5	1
	Plan(s)	R26	Residential	Bedroom	1.0	1.14	55%	9.60	Yes	7	1
	Plan(s)	R27	Residential	Bedroom	1.0	1.46	85%	10.07	Yes	21	7
	Plan(s)	R28	Residential	LKD	1.5	3.09	91%	Exempt: Dual Aspect	Yes	42	8
	Plan(s)	R29	Residential	Studio	1.5	1.70	92%	Exempt: Dual Aspect	Yes	20	9

Orange or Red = Below guidelines (Orange = within 20% of guideline)

Grey APSH = not a main living room

Property & room attributes					Daylight/Sunlight (BRE 2011)						
Floor	Flat/Unit no.	Room ref.	Property type	Room use	ADF		NSL (% room)	Room depth criterion		APSH room	
					Target (%)	ADF (%)		Limit (current) (m)	Criterion met?	Annual (%)	Winter (%)
F04	Plan(s)	R30	Residential	Bedroom	1.0	2.09	79%	Exempt: Dual Aspect	Yes	1	0
	Plan(s)	R31	Residential	LKD	1.5	1.25	72%	Exempt: Dual Aspect	Yes	3	0
	Plan(s)	R32	Residential	Bedroom	1.0	0.13	2%	11.65	Yes	0	0
	Plan(s)	R1	Residential	Studio	1.5	1.76	92%	Exempt: Dual Aspect	Yes	13	1
	Plan(s)	R2	Residential	Bedroom	1.0	0.88	95%	9.83	Yes	2	1
	Plan(s)	R3	Residential	LKD	1.5	2.14	100%	Exempt: Dual Aspect	Yes	26	4
	Plan(s)	R4	Residential	Bedroom	1.0	2.06	98%	9.41	Yes	17	0
	Plan(s)	R5	Residential	Bedroom	1.0	0.85	96%	Exempt: Dual Aspect	Yes	2	0
	Plan(s)	R6	Residential	LKD	1.5	2.18	86%	Exempt: Dual Aspect	Yes	23	2
	Plan(s)	R7	Residential	Bedroom	1.0	1.97	81%	9.41	Yes	14	0
	Plan(s)	R8	Residential	Bedroom	1.0	0.85	69%	Exempt: Dual Aspect	Yes	4	1
	Plan(s)	R9	Residential	LKD	1.5	2.05	47%	Exempt: Dual Aspect	Yes	17	4
	Plan(s)	R10	Residential	Bedroom	1.0	1.87	42%	9.40	Yes	10	2
	Plan(s)	R11	Residential	Bedroom	1.0	0.78	39%	9.91	Yes	2	2
	Plan(s)	R12	Residential	LKD	1.5	7.14	99%	Exempt: Dual Aspect	Yes	68	27
	Plan(s)	R13	Residential	Bedroom	1.0	4.01	97%	11.20	Yes	57	25
	Plan(s)	R14	Residential	Bedroom	1.0	2.01	97%	10.76	Yes	19	19
	Plan(s)	R15	Residential	LKD	1.5	2.67	99%	Exempt: Dual Aspect	Yes	60	27
	Plan(s)	R16	Residential	Bedroom	1.0	1.22	89%	10.10	Yes	9	9
	Plan(s)	R17	Residential	LKD	1.5	1.75	99%	10.80	Yes	57	25
	Plan(s)	R18	Residential	LKD	1.5	1.44	99%	10.08	Yes	11	11
	Plan(s)	R19	Residential	Bedroom	1.0	3.48	91%	11.27	Yes	0	0
	Plan(s)	R20	Residential	Bedroom	1.0	1.98	60%	10.14	Yes	0	0
	Plan(s)	R21	Residential	Studio	1.5	1.93	86%	Exempt: Dual Aspect	Yes	6	0
	Plan(s)	R22	Residential	LKD	1.5	1.28	62%	10.47	Yes	8	2
	Plan(s)	R23	Residential	Bedroom	1.0	2.25	86%	9.70	Yes	10	2
	Plan(s)	R24	Residential	Bedroom	1.0	2.18	85%	9.50	Yes	13	2
	Plan(s)	R25	Residential	LKD	1.5	1.16	58%	10.34	Yes	7	3
	Plan(s)	R26	Residential	Bedroom	1.0	1.19	61%	9.60	Yes	8	2
	Plan(s)	R27	Residential	Bedroom	1.0	1.60	92%	10.07	Yes	23	8
	Plan(s)	R28	Residential	LKD	1.5	3.23	91%	Exempt: Dual Aspect	Yes	48	12
	Plan(s)	R29	Residential	Studio	1.5	1.80	97%	Exempt: Dual Aspect	Yes	18	6
	Plan(s)	R30	Residential	Bedroom	1.0	2.43	81%	Exempt: Dual Aspect	Yes	3	0
	Plan(s)	R31	Residential	LKD	1.5	1.51	78%	Exempt: Dual Aspect	Yes	4	0
	Plan(s)	R32	Residential	Bedroom	1.0	0.21	4%	11.65	Yes	0	0