

ARCHITECTONICS

CIAT Chartered Architectural Practice
& Historic Buildings Consultancy

6 Church Street,
Caversham,
Berkshire.
RG4 8AT

SUPPORTING IMAGES

August 2025



Figure 1. Image showing the installation of the 25mm diameter MDPE water supply pipe in a 457mm wide trench through the existing Dining Room floor refer to Construction Detail A.



Figure 2. Image showing the installation of the 25mm diameter MDPE water supply pipe in a 225mm wide trench through the existing Kitchen floor to be connected to the existing stop cock refer to construction Detail B.



Figure 3. Image showing the existing C20 plasterboard ceiling & wall finish removed exposing the existing walls and roof rafters. The existing rafters have been inspected and are in good condition, no replacements or repairs are required.