

From: Paul Reed <[REDACTED]>

Sent: 25 July 2025 08:40

To: Steve Rhodes <[REDACTED]>

Subject: UKP11670 Reading Golf Club

Hi Steve

I am writing to you with regards to your request on additional capacity from the substation.

Our design team have completed their network checks, and it has been confirmed with no uncertainty there is no additional capacity utilising the substation on the development. Any additional connections would have a detrimental effect on the current load already issued, ultimately resulting in voltage drop and poor performance.

Please let me know if there is anything further you need from me, thanks

Kind Regards,

UKPS

Paul Reed
Regional Operations Manager South East

T: [REDACTED]

E: [REDACTED] | W: <https://ukpowersolutions.co.uk/>

My working hours are Monday-Thursday, 8:00am – 4:30pm, and Friday 8.00am-4.00pm

T: [REDACTED] | H: 0845 257 7105 | E: [REDACTED]
River View House, Bonds Mill Estate, Stonehouse, Gloucestershire. GL10 3RF
www.ukpowersolutions.co.uk

UKPS
UK POWER SOLUTIONS



Please consider the environment before printing this e-mail

This message and any files transmitted with it are confidential and intended solely for the individual or entity to whom they are addressed. If you have received this in error, you should not disseminate or copy this email.

Please notify the sender immediately and delete this email from your system. Please also note that any opinions presented in this email are solely those of the author and do not necessarily represent those of UK Power Solutions Ltd.

Email transmission cannot be guaranteed to be secure, or error free as information could be intercepted, corrupted, lost, destroyed, late in arriving or incomplete as a result of the transmission process.

The sender therefore does not accept liability for any errors or omissions in the contents of this message which arise as a result of email transmission. Finally, the recipient should check this email and any attachments for viruses. UK Power Solutions Ltd accepts no liability for any damage caused by any virus transmitted by this email. Company Reg No. 06256696 | VAT Reg No. 997 336 559