

CONDITION ONE.

PLEASE SEE DIAGRAM FOR LOCATION OF EXTRACTOR FAN. EXHAUST PRECISE LOCATION TO BE DETERMINED BUT IS INTENDED TO BE THROUGH EAVES AND FINISHED USING TILE VENT THROUGH ROOF. ALSO SUPPLIED PICTURES OF EXTRACTOR TO BE USED.

CONDITION TWO.

PLEASE SEE ATTACHED INFORMATION MARKED (2)

CONDITION THREE.

PLEASE SEE ATTACHED PHOTOS OF ORIGINAL SKIRTING BOARD WHICH WILL BE REPLICATED WHERE NECESSARY

NO WALLS WILL NEED TO BE REMOVED FOR THE INSULATION AS THIS WILL BE GOING INSIDE THE NEWLY CREATED WALL BETWEEN BATHROOM AND BEDROOM.

IT IS POSSIBLE TO INSTALL THE MOISTURE RESISTANT BLASTERBOARD ON ORIGINAL CEILING IF REQUIRED, HOWEVER THIS IS NOT BELIEVED TO BE AN ORIGINAL CEILING.

CEMENT BOARD FOR FLOOR WILL BE GOING ON TOP OF ORIGINAL FLOOR ORIGINAL WALLS FOR SHOWER ENCLOSURE WILL ALSO BE LINED FOR
TILING