


Block Compliance



Block Reference	Alloway Courtyard	Issued on Date	16/10/2025
Block Name			
Calculation Type	New Build (As Built)		

Assessor Details	Mr. Andrew Whittemore	Assessor ID	CK54-0001
Client	Hydrock, -, Merchants' House North, Wapping Road, Bristol, BS1 4RW		

Block Compliance Report - DER				
Block Reference: Alloway Courtyard		Block Name:		
Property-Assessment Reference	Floor area (m ²)	DER (kgCO ₂ /m ²)	TER (kgCO ₂ /m ²)	% DER/TER
_LG 01.12 - LG 01.12	93.06	4.49	12.40	63.79 %
_LG 01.14 - LG 01.14	69.27	4.40	13.40	67.16 %
0G 00.01 - G 00.01	69.49	3.10	12.90	75.97 %
0G 00.02 - G 00.02	49.10	3.35	14.74	77.27 %
0G 00.03 - G 00.03	69.49	3.11	12.62	75.36 %
0G 00.04 - G 00.04	106.52	2.83	10.00	71.70 %
0G 00.05 - G 00.05	69.27	2.90	11.83	75.49 %
0G 00.06 - G 00.06	72.41	2.78	12.66	78.04 %
0G 00.07 - G 00.07	71.75	2.88	12.68	77.29 %
0G 00.08 - G 00.08	48.45	3.40	15.26	77.72 %
0G 00.09 - G 00.09	50.23	3.46	14.93	76.83 %
0G 00.10 - G 00.10	65.67	3.04	12.24	75.16 %
0G 00.11 - G 00.11	43.29	3.09	14.28	78.36 %
1F 01.01 - 1F 01.01	69.49	2.34	10.26	77.19 %
1F 01.02 - 1F 01.02	49.10	2.74	12.32	77.76 %
1F 01.03 - 1F 01.03	69.49	2.42	10.25	76.39 %
1F 01.04 - 1F 01.04	106.52	3.06	9.94	69.22 %
1F 01.05 - 1F 01.05	69.27	2.99	11.65	74.33 %
1F 01.06 - 1F 01.06	72.41	2.49	10.47	76.22 %
1F 01.07 - 1F 01.07	71.75	2.38	10.23	76.74 %
1F 01.08 - 1F 01.08	48.45	2.75	12.42	77.86 %
1F 01.09 - 1F 01.09	50.23	2.67	12.02	77.79 %

Block Compliance

1F 01.10 - 1F 01.10	45.60	2.79	12.74	78.10 %
1F 01.11 - 1F 01.11	44.79	2.84	13.03	78.20 %
1F 01.12 - 1F 01.12	44.79	2.98	13.35	77.68 %
1F 01.13 - 1F 01.13	74.85	3.46	11.77	70.60 %
1F 01.14 - 1F 01.14	75.52	3.02	11.08	72.74 %
1F 01.15 - 1F 01.15	44.74	2.85	12.44	77.09 %
1F 01.16 - 1F 01.16	44.74	2.71	12.33	78.02 %
1F 01.17 - 1F 01.17	62.76	2.40	10.32	76.74 %
1F 01.18 - 1F 01.18	64.27	2.88	11.38	74.69 %
1F 01.19 - 1F 01.19	43.29	2.92	13.26	77.98 %
2F 02.01 - 2F 02.01	44.58	2.72	12.92	78.95 %
2F 02.02 - 2F 02.02	69.49	2.35	10.34	77.27 %
2F 02.03 - 2F 02.03	49.10	2.61	12.09	78.41 %
2F 02.04 - 2F 02.04	69.49	2.35	10.33	77.25 %
2F 02.08 - 2F 02.08	71.75	2.30	10.23	77.52 %
2F 02.09 - 2F 02.09	48.45	2.63	12.31	78.64 %
2F 02.10 - 2F 02.10	50.23	2.60	12.03	78.39 %
3F 03.01 - 3F 03.01	44.58	2.80	13.03	78.51 %
3F 03.05 - 3F 03.05	52.99	5.23	16.69	68.66 %
3F 03.06 - 3F 03.06	50.88	4.06	15.09	73.09 %
3F 03.07 - 3F 03.07	69.27	4.79	14.95	67.96 %
3F 03.08 - 3F 03.08	72.41	3.78	13.56	72.12 %
6F 06.04 - 6F 06.04	69.49	2.79	11.48	75.70 %
6F 06.05 - 6F 06.05	71.75	2.70	11.39	76.29 %
7F 07.01 - 7F 07.01	44.58	2.74	12.80	78.59 %
7F 07.02 - 7F 07.02	69.49	2.35	10.18	76.92 %
7F 07.04 - 7F 07.04	45.31	3.40	14.33	76.27 %
7F 07.05 - 7F 07.05	47.02	3.39	14.00	75.79 %

Block Compliance

7F 07.06 - 7F 07.06	48.45	2.64	12.19	78.34 %
7F 07.07 - 7F 07.07	50.23	2.60	11.91	78.17 %
7F 07.08 - 7F 07.08	45.60	2.72	12.61	78.43 %
8F 08.01 - 8F 08.01	44.58	3.91	15.51	74.79 %
8F 08.02 - 8F 08.02	69.49	3.61	12.83	71.86 %
8F 08.03 - 8F 08.03	49.10	3.80	14.83	74.38 %
8F 08.04 - 8F 08.04	45.31	5.14	17.46	70.56 %
8F 08.05 - 8F 08.05	47.02	5.09	17.10	70.23 %
8F 08.06 - 8F 08.06	48.45	3.87	14.95	74.11 %
8F 08.07 - 8F 08.07	50.23	3.72	14.64	74.59 %
8F 08.08 - 8F 08.08	45.60	3.82	15.32	75.07 %
8F 08.16 - 8F 08.16	64.27	4.51	14.38	68.64 %
8F 08.17 - 8F 08.17	43.29	4.20	16.15	73.99 %
9F 09.01 - 9F 09.01	44.79	4.02	15.87	74.67 %
9F 09.02 - 9F 09.02	44.79	4.36	16.18	73.05 %
9F 09.03 - 9F 09.03	74.85	5.03	14.49	65.29 %
9F 09.04 - 9F 09.04	75.52	4.77	14.04	66.03 %
9F 09.05 - 9F 09.05	44.74	3.84	14.98	74.37 %
9F 09.06 - 9F 09.06	44.74	3.66	14.91	75.45 %
9F 09.07 - 9F 09.07	62.76	4.34	14.23	69.50 %
2F 02.05 - 2F 02.05	106.52	2.70	9.94	72.84 %
2F 02.06 - 2F 02.06	69.27	2.80	11.65	75.97 %
2F 02.07 - 2F 02.07	72.41	2.34	10.47	77.65 %
2F 02.11 - 2F 02.11	45.60	2.70	12.74	78.81 %
4F 04.08 - 4F 04.08	45.60	2.70	12.74	78.81 %
5F 05.08 - 5F 05.08	45.60	2.70	12.74	78.81 %
6F 06.08 - 6F 06.08	45.60	2.70	12.74	78.81 %
2F 02.12 - 2F 02.12	44.79	2.72	13.03	79.13 %

Block Compliance

3F 03.13 - 3F 03.13	44.79	2.81	13.03	78.43 %
4F 04.09 - 4F 04.09	44.79	2.72	13.03	79.13 %
5F 05.09 - 5F 05.09	44.79	2.73	13.03	79.05 %
6F 06.09 - 6F 06.09	44.79	2.73	13.03	79.05 %
7F 07.09 - 7F 07.09	44.79	2.75	13.03	78.89 %
8F 08.09 - 8F 08.09	44.79	2.77	13.03	78.74 %
2F 02.13 - 2F 02.13	44.79	2.81	13.35	78.95 %
3F 03.14 - 3F 03.14	44.79	2.99	13.35	77.60 %
4F 04.10 - 4F 04.10	44.79	2.81	13.35	78.95 %
5F 05.10 - 5F 05.10	44.79	2.82	13.35	78.88 %
6F 06.10 - 6F 06.10	44.79	2.82	13.35	78.88 %
7F 07.10 - 7F 07.10	44.79	2.85	13.35	78.65 %
8F 08.10 - 8F 08.10	44.79	2.90	13.35	78.28 %
5F 05.12 - 5F 05.12	75.52	2.95	11.08	73.38 %
2F 02.14 - 2F 02.14	74.85	3.14	11.77	73.32 %
4F 04.11 - 4F 04.11	74.85	3.20	11.77	72.81 %
5F 05.11 - 5F 05.11	74.85	3.39	11.77	71.20 %
6F 06.11 - 6F 06.11	74.85	3.35	11.77	71.54 %
7F 07.11 - 7F 07.11	74.85	3.42	11.77	70.94 %
8F 08.11 - 8F 08.11	74.85	3.45	11.77	70.69 %
7F 07.12 - 7F 07.12	75.52	3.00	11.08	72.92 %
4F 04.12 - 4F 04.12	75.52	2.88	11.08	74.01 %
6F 06.12 - 6F 06.12	75.52	3.04	11.08	72.56 %
8F 08.12 - 8F 08.12	75.52	3.08	11.08	72.20 %
2F 02.16 - 2F 02.16	44.74	2.71	12.44	78.22 %
3F 03.17 - 3F 03.17	44.74	2.72	12.44	78.14 %
4F 04.13 - 4F 04.13	44.74	2.70	12.44	78.30 %
5F 05.13 - 5F 05.13	44.74	2.70	12.44	78.30 %

Block Compliance

6F 06.13 - 6F 06.13	44.74	2.70	12.44	78.30 %
7F 07.13 - 7F 07.13	44.74	2.71	12.44	78.22 %
8F 08.13 - 8F 08.13	44.74	2.70	12.44	78.30 %
2F 02.17 - 2F 02.17	44.74	2.69	12.33	78.18 %
3F 03.18 - 3F 03.18	44.74	2.69	12.33	78.18 %
4F 04.14 - 4F 04.14	44.74	2.68	12.33	78.26 %
5F 05.14 - 5F 05.14	44.74	2.69	12.33	78.18 %
6F 06.14 - 6F 06.14	44.74	2.69	12.33	78.18 %
7F 07.14 - 7F 07.14	44.74	2.70	12.33	78.10 %
8F 08.14 - 8F 08.14	44.74	2.69	12.33	78.18 %
2F 02.18 - 2F 02.18	62.76	2.37	10.32	77.03 %
3F 03.19 - 3F 03.19	62.76	2.37	10.32	77.03 %
4F 04.15 - 4F 04.15	62.76	2.39	10.32	76.84 %
5F 05.15 - 5F 05.15	62.76	2.38	10.32	76.94 %
6F 06.15 - 6F 06.15	62.76	2.38	10.32	76.94 %
7F 07.15 - 7F 07.15	62.76	2.38	10.32	76.94 %
8F 08.15 - 8F 08.15	62.76	2.38	10.32	76.94 %
2F 02.19 - 2F 02.19	64.27	2.85	11.38	74.96 %
3F 03.20 - 3F 03.20	64.27	2.88	11.38	74.69 %
4F 04.16 - 4F 04.16	64.27	2.91	11.38	74.43 %
5F 05.16 - 5F 05.16	64.27	2.90	11.38	74.52 %
6F 06.16 - 6F 06.16	64.27	2.92	11.38	74.34 %
7F 07.16 - 7F 07.16	64.27	2.97	11.38	73.90 %
2F 02.20 - 2F 02.20	43.29	2.80	13.26	78.88 %
3F 03.21 - 3F 03.21	43.29	2.87	13.26	78.36 %
4F 04.17 - 4F 04.17	43.29	2.79	13.26	78.96 %
5F 05.17 - 5F 05.17	43.29	2.79	13.26	78.96 %
6F 06.17 - 6F 06.17	43.29	2.79	13.26	78.96 %

7F 07.17 - 7F 07.17	43.29	2.88	13.26	78.28 %
3F 03.02 - 3F 03.02	69.49	2.36	10.26	77.00 %
3F 03.03 - 3F 03.03	49.10	2.68	12.32	78.25 %
3F 03.04 - 3F 03.04	69.49	2.37	10.25	76.88 %
5F 05.01 - 5F 05.01	44.58	2.76	13.03	78.82 %
5F 05.02 - 5F 05.02	69.49	2.37	10.26	76.90 %
5F 05.04 - 5F 05.04	69.49	2.37	10.25	76.88 %
5F 05.03 - 5F 05.03	49.10	2.68	12.32	78.25 %
3F 03.09 - 3F 03.09	71.75	2.29	10.23	77.61 %
5F 05.05 - 5F 05.05	71.75	2.33	10.23	77.22 %
3F 03.10 - 3F 03.10	48.45	2.71	12.42	78.18 %
5F 05.06 - 5F 05.06	48.45	2.68	12.42	78.42 %
3F 03.11 - 3F 03.11	50.23	2.63	12.02	78.12 %
5F 05.07 - 5F 05.07	50.23	2.61	12.02	78.29 %
4F 04.01 - 4F 04.01	44.58	2.74	12.92	78.79 %
6F 06.01 - 6F 06.01	44.58	2.74	12.92	78.79 %
4F 04.02 - 4F 04.02	69.49	2.34	10.34	77.37 %
6F 06.02 - 6F 06.02	69.49	2.37	10.34	77.08 %
4F 04.03 - 4F 04.03	49.10	2.60	12.09	78.49 %
6F 06.03 - 6F 06.03	49.10	2.63	12.09	78.25 %
4F 04.04 - 4F 04.04	69.49	2.34	10.33	77.35 %
4F 04.05 - 4F 04.05	106.52	2.67	9.94	73.14 %
4F 04.06 - 4F 04.06	48.45	2.63	12.31	78.64 %
6F 06.06 - 6F 06.06	48.45	2.67	12.31	78.31 %
4F 04.07 - 4F 04.07	50.23	2.58	12.03	78.55 %
6F 06.07 - 6F 06.07	50.23	2.61	12.03	78.30 %
3F 03.12 - 3F 03.12	45.60	2.72	12.74	78.65 %
7F 07.03 - 7F 07.03	49.10	2.63	12.09	78.25 %

Block Compliance

3F 03.15 - 3F 03.15	74.85	3.23	11.77	72.56 %
2F 02.15 - 2F 02.15	75.52	2.82	11.08	74.55 %
3F 03.16 - 3F 03.16	75.52	2.91	11.08	73.74 %
Totals:	9492.03	490.37	2047.14	
Average DER = 2.98 kgCO ₂ /m ²	% DER/TER	PASS		
Average TER = 12.18 kgCO ₂ /m ²	75.57 %			

Block Compliance Report - DFEE				
Block Reference: Alloway Courtyard	Block Name:			
Property-Assessment Reference	Floor area (m ²)	DFEE (kWh/m ² /yr)	TFEE (kWh/m ² /yr)	% DFEE/TFEE
_LG 01.12 - LG 01.12	93.06	32.90	32.51	-1.21 %
_LG 01.14 - LG 01.14	69.27	30.89	30.16	-2.42 %
0G 00.01 - G 00.01	69.49	21.18	28.13	24.70 %
0G 00.02 - G 00.02	49.10	20.68	28.00	26.16 %
0G 00.03 - G 00.03	69.49	20.57	26.83	23.36 %
0G 00.04 - G 00.04	106.52	22.80	24.77	7.97 %
0G 00.05 - G 00.05	69.27	21.12	23.34	9.51 %
0G 00.06 - G 00.06	72.41	20.02	27.44	27.02 %
0G 00.07 - G 00.07	71.75	21.01	27.88	24.65 %
0G 00.08 - G 00.08	48.45	22.08	30.49	27.59 %
0G 00.09 - G 00.09	50.23	22.08	29.93	26.23 %
0G 00.10 - G 00.10	65.67	19.57	24.63	20.55 %
0G 00.11 - G 00.11	43.29	16.81	21.91	23.26 %
1F 01.01 - 1F 01.01	69.49	13.58	15.79	14.01 %
1F 01.02 - 1F 01.02	49.10	14.87	16.78	11.38 %
1F 01.03 - 1F 01.03	69.49	13.92	15.74	11.56 %

1F 01.04 - 1F 01.04	106.52	23.13	24.44	5.38 %
1F 01.05 - 1F 01.05	69.27	20.27	22.24	8.84 %
1F 01.06 - 1F 01.06	72.41	14.36	16.89	14.96 %
1F 01.07 - 1F 01.07	71.75	14.37	16.36	12.20 %
1F 01.08 - 1F 01.08	48.45	14.95	16.91	11.58 %
1F 01.09 - 1F 01.09	50.23	13.58	15.60	12.97 %
1F 01.10 - 1F 01.10	45.60	14.20	16.16	12.14 %
1F 01.11 - 1F 01.11	44.79	14.16	16.40	13.68 %
1F 01.12 - 1F 01.12	44.79	16.61	18.49	10.20 %
1F 01.13 - 1F 01.13	74.85	24.73	25.70	3.76 %
1F 01.14 - 1F 01.14	75.52	21.22	22.59	6.08 %
1F 01.15 - 1F 01.15	44.74	13.63	13.55	-0.64 %
1F 01.16 - 1F 01.16	44.74	10.06	12.14	17.13 %
1F 01.17 - 1F 01.17	62.76	11.25	12.99	13.42 %
1F 01.18 - 1F 01.18	64.27	19.46	20.37	4.46 %
1F 01.19 - 1F 01.19	43.29	15.42	17.03	9.45 %
2F 02.01 - 2F 02.01	44.58	13.74	16.34	15.94 %
2F 02.02 - 2F 02.02	69.49	14.29	16.46	13.18 %
2F 02.03 - 2F 02.03	49.10	12.15	14.89	18.37 %
2F 02.04 - 2F 02.04	69.49	14.23	16.41	13.26 %
2F 02.08 - 2F 02.08	71.75	13.96	16.40	14.88 %
2F 02.09 - 2F 02.09	48.45	13.29	15.94	16.64 %
2F 02.10 - 2F 02.10	50.23	13.07	15.66	16.53 %
3F 03.01 - 3F 03.01	44.58	15.18	17.30	12.23 %

Block Compliance

3F 03.05 - 3F 03.05	52.99	35.72	39.83	10.33 %
3F 03.06 - 3F 03.06	50.88	26.11	29.97	12.88 %
3F 03.07 - 3F 03.07	69.27	33.07	37.40	11.57 %
3F 03.08 - 3F 03.08	72.41	26.20	31.31	16.31 %
6F 06.04 - 6F 06.04	69.49	18.71	21.79	14.14 %
6F 06.05 - 6F 06.05	71.75	18.46	21.83	15.43 %
7F 07.01 - 7F 07.01	44.58	13.04	15.36	15.15 %
7F 07.02 - 7F 07.02	69.49	13.01	15.15	14.15 %
7F 07.04 - 7F 07.04	45.31	21.61	24.17	10.59 %
7F 07.05 - 7F 07.05	47.02	21.35	23.70	9.91 %
7F 07.06 - 7F 07.06	48.45	12.72	14.99	15.11 %
7F 07.07 - 7F 07.07	50.23	12.16	14.67	17.14 %
7F 07.08 - 7F 07.08	45.60	12.76	15.10	15.50 %
8F 08.01 - 8F 08.01	44.58	24.12	28.12	14.23 %
8F 08.02 - 8F 08.02	69.49	23.87	27.42	12.92 %
8F 08.03 - 8F 08.03	49.10	23.68	27.76	14.69 %
8F 08.04 - 8F 08.04	45.31	33.38	38.31	12.87 %
8F 08.05 - 8F 08.05	47.02	32.97	37.73	12.62 %
8F 08.06 - 8F 08.06	48.45	23.91	27.98	14.55 %
8F 08.07 - 8F 08.07	50.23	23.32	27.48	15.13 %
8F 08.08 - 8F 08.08	45.60	23.68	27.91	15.14 %
8F 08.16 - 8F 08.16	64.27	31.11	34.12	8.80 %
8F 08.17 - 8F 08.17	43.29	26.07	30.21	13.69 %

9F 09.01 - 9F 09.01	44.79	25.24	29.69	14.99 %
9F 09.02 - 9F 09.02	44.79	27.63	31.55	12.42 %
9F 09.03 - 9F 09.03	74.85	34.93	37.93	7.90 %
9F 09.04 - 9F 09.04	75.52	32.73	35.84	8.69 %
9F 09.05 - 9F 09.05	44.74	22.39	25.76	13.08 %
9F 09.06 - 9F 09.06	44.74	20.65	24.76	16.57 %
9F 09.07 - 9F 09.07	62.76	27.86	32.06	13.12 %
2F 02.05 - 2F 02.05	106.52	22.19	24.44	9.23 %
2F 02.06 - 2F 02.06	69.27	19.84	22.24	10.80 %
2F 02.07 - 2F 02.07	72.41	13.54	16.89	19.80 %
2F 02.11 - 2F 02.11	45.60	13.52	16.16	16.33 %
4F 04.08 - 4F 04.08	45.60	13.48	16.16	16.58 %
5F 05.08 - 5F 05.08	45.60	13.48	16.16	16.55 %
6F 06.08 - 6F 06.08	45.60	13.51	16.16	16.36 %
2F 02.12 - 2F 02.12	44.79	13.17	16.40	19.71 %
3F 03.13 - 3F 03.13	44.79	13.95	16.40	14.96 %
4F 04.09 - 4F 04.09	44.79	13.21	16.40	19.46 %
5F 05.09 - 5F 05.09	44.79	13.35	16.40	18.56 %
6F 06.09 - 6F 06.09	44.79	13.27	16.40	19.07 %
7F 07.09 - 7F 07.09	44.79	13.55	16.40	17.36 %
8F 08.09 - 8F 08.09	44.79	13.67	16.40	16.62 %
2F 02.13 - 2F 02.13	44.79	15.73	18.49	14.95 %
3F 03.14 - 3F 03.14	44.79	16.63	18.49	10.04 %

4F 04.10 - 4F 04.10	44.79	15.73	18.49	14.92 %
5F 05.10 - 5F 05.10	44.79	15.80	18.49	14.56 %
6F 06.10 - 6F 06.10	44.79	15.81	18.49	14.50 %
7F 07.10 - 7F 07.10	44.79	15.95	18.49	13.74 %
8F 08.10 - 8F 08.10	44.79	16.23	18.49	12.24 %
5F 05.12 - 5F 05.12	75.52	21.07	22.59	6.75 %
2F 02.14 - 2F 02.14	74.85	23.89	25.70	7.02 %
4F 04.11 - 4F 04.11	74.85	24.05	25.70	6.40 %
5F 05.11 - 5F 05.11	74.85	24.54	25.70	4.51 %
6F 06.11 - 6F 06.11	74.85	24.44	25.70	4.91 %
7F 07.11 - 7F 07.11	74.85	24.64	25.70	4.11 %
8F 08.11 - 8F 08.11	74.85	24.71	25.70	3.85 %
7F 07.12 - 7F 07.12	75.52	21.22	22.59	6.08 %
4F 04.12 - 4F 04.12	75.52	20.83	22.59	7.78 %
6F 06.12 - 6F 06.12	75.52	21.34	22.59	5.53 %
8F 08.12 - 8F 08.12	75.52	21.46	22.59	5.02 %
2F 02.16 - 2F 02.16	44.74	11.57	13.55	14.58 %
3F 03.17 - 3F 03.17	44.74	11.66	13.55	13.90 %
4F 04.13 - 4F 04.13	44.74	11.51	13.55	15.06 %
5F 05.13 - 5F 05.13	44.74	11.47	13.55	15.31 %
6F 06.13 - 6F 06.13	44.74	11.50	13.55	15.09 %
7F 07.13 - 7F 07.13	44.74	11.62	13.55	14.20 %
8F 08.13 - 8F 08.13	44.74	11.54	13.55	14.81 %
2F 02.17 - 2F 02.17	44.74	9.66	12.14	20.44 %
3F 03.18 - 3F 03.18	44.74	9.55	12.14	21.33 %

4F 04.14 - 4F 04.14	44.74	9.43	12.14	22.33 %
5F 05.14 - 5F 05.14	44.74	9.60	12.14	20.91 %
6F 06.14 - 6F 06.14	44.74	9.65	12.14	20.51 %
7F 07.14 - 7F 07.14	44.74	9.87	12.14	18.64 %
8F 08.14 - 8F 08.14	44.74	9.57	12.14	21.16 %
2F 02.18 - 2F 02.18	62.76	11.00	12.99	15.32 %
3F 03.19 - 3F 03.19	62.76	11.00	12.99	15.38 %
4F 04.15 - 4F 04.15	62.76	11.16	12.99	14.10 %
5F 05.15 - 5F 05.15	62.76	11.10	12.99	14.57 %
6F 06.15 - 6F 06.15	62.76	11.08	12.99	14.75 %
7F 07.15 - 7F 07.15	62.76	11.06	12.99	14.90 %
8F 08.15 - 8F 08.15	62.76	11.09	12.99	14.66 %
2F 02.19 - 2F 02.19	64.27	19.39	20.37	4.81 %
3F 03.20 - 3F 03.20	64.27	19.47	20.37	4.43 %
4F 04.16 - 4F 04.16	64.27	19.56	20.37	3.97 %
5F 05.16 - 5F 05.16	64.27	19.51	20.37	4.22 %
6F 06.16 - 6F 06.16	64.27	19.58	20.37	3.90 %
7F 07.16 - 7F 07.16	64.27	19.71	20.37	3.24 %
2F 02.20 - 2F 02.20	43.29	14.69	17.03	13.73 %
3F 03.21 - 3F 03.21	43.29	15.11	17.03	11.27 %
4F 04.17 - 4F 04.17	43.29	14.59	17.03	14.29 %
5F 05.17 - 5F 05.17	43.29	14.59	17.03	14.32 %
6F 06.17 - 6F 06.17	43.29	14.61	17.03	14.23 %
7F 07.17 - 7F 07.17	43.29	15.21	17.03	10.70 %

3F 03.02 - 3F 03.02	69.49	13.66	15.79	13.47 %
3F 03.03 - 3F 03.03	49.10	14.51	16.78	13.50 %
3F 03.04 - 3F 03.04	69.49	13.72	15.74	12.86 %
5F 05.01 - 5F 05.01	44.58	14.93	17.30	13.68 %
5F 05.02 - 5F 05.02	69.49	13.73	15.79	13.06 %
5F 05.04 - 5F 05.04	69.49	13.72	15.74	12.86 %
5F 05.03 - 5F 05.03	49.10	14.51	16.78	13.50 %
3F 03.09 - 3F 03.09	71.75	13.81	16.36	15.59 %
5F 05.05 - 5F 05.05	71.75	14.11	16.36	13.76 %
3F 03.10 - 3F 03.10	48.45	14.70	16.91	13.08 %
5F 05.06 - 5F 05.06	48.45	14.54	16.91	14.02 %
3F 03.11 - 3F 03.11	50.23	13.28	15.60	14.90 %
5F 05.07 - 5F 05.07	50.23	13.12	15.60	15.93 %
4F 04.01 - 4F 04.01	44.58	13.86	16.34	15.21 %
6F 06.01 - 6F 06.01	44.58	13.84	16.34	15.31 %
4F 04.02 - 4F 04.02	69.49	14.20	16.46	13.70 %
6F 06.02 - 6F 06.02	69.49	14.37	16.46	12.71 %
4F 04.03 - 4F 04.03	49.10	11.92	14.89	19.95 %
6F 06.03 - 6F 06.03	49.10	12.36	14.89	16.99 %
4F 04.04 - 4F 04.04	69.49	14.19	16.41	13.54 %
4F 04.05 - 4F 04.05	106.52	22.12	24.44	9.50 %
4F 04.06 - 4F 04.06	48.45	13.26	15.94	16.83 %
6F 06.06 - 6F 06.06	48.45	13.62	15.94	14.55 %

Block Compliance

4F 04.07 - 4F 04.07	50.23	12.87	15.66	17.78 %
6F 06.07 - 6F 06.07	50.23	13.19	15.66	15.72 %
3F 03.12 - 3F 03.12	45.60	13.73	16.16	15.05 %
7F 07.03 - 7F 07.03	49.10	12.40	14.89	16.70 %
3F 03.15 - 3F 03.15	74.85	24.11	25.70	6.17 %
2F 02.15 - 2F 02.15	75.52	20.63	22.59	8.69 %
3F 03.16 - 3F 03.16	75.52	20.89	22.59	7.55 %
Totals:	9492.03	2871.21	3299.16	
Average DFEE = 18.00 kWh/m ² /yr	% DFEE/TFEE	PASS		
Average TFEE = 20.52 kWh/m ² /yr	12.31 %			

Block Compliance Report - DPER				
Block Reference: Alloway Courtyard	Block Name:			
Property-Assessment Reference	Floor area (m ²)	DPER (kWh/m ² /yr)	TPER (kWh/m ² /yr)	% DPER/TPER
_LG 01.12 - LG 01.12	93.06	46.52	67.17	30.74 %
_LG 01.14 - LG 01.14	69.27	45.92	72.98	37.08 %
0G 00.01 - G 00.01	69.49	32.72	70.33	53.48 %
0G 00.02 - G 00.02	49.10	35.49	80.64	55.99 %
0G 00.03 - G 00.03	69.49	32.84	68.82	52.28 %
0G 00.04 - G 00.04	106.52	29.65	54.04	45.13 %
0G 00.05 - G 00.05	69.27	30.66	64.38	52.38 %
0G 00.06 - G 00.06	72.41	29.52	68.98	57.20 %
0G 00.07 - G 00.07	71.75	30.50	69.06	55.84 %
0G 00.08 - G 00.08	48.45	35.98	83.35	56.83 %
0G 00.09 - G 00.09	50.23	36.56	81.58	55.19 %
0G 00.10 - G 00.10	65.67	32.09	66.62	51.83 %
0G 00.11 - G 00.11	43.29	33.02	78.26	57.81 %
1F 01.01 - 1F 01.01	69.49	25.13	56.01	55.13 %

1F 01.02 - 1F 01.02	49.10	29.37	67.47	56.47 %
1F 01.03 - 1F 01.03	69.49	25.92	55.95	53.67 %
1F 01.04 - 1F 01.04	106.52	31.99	53.75	40.48 %
1F 01.05 - 1F 01.05	69.27	31.57	63.45	50.24 %
1F 01.06 - 1F 01.06	72.41	26.60	57.18	53.48 %
1F 01.07 - 1F 01.07	71.75	25.50	55.82	54.32 %
1F 01.08 - 1F 01.08	48.45	29.52	68.04	56.61 %
1F 01.09 - 1F 01.09	50.23	28.68	65.91	56.49 %
1F 01.10 - 1F 01.10	45.60	29.95	69.84	57.12 %
1F 01.11 - 1F 01.11	44.79	30.44	71.55	57.46 %
1F 01.12 - 1F 01.12	44.79	31.88	73.12	56.40 %
1F 01.13 - 1F 01.13	74.85	36.21	63.95	43.38 %
1F 01.14 - 1F 01.14	75.52	31.78	60.20	47.21 %
1F 01.15 - 1F 01.15	44.74	30.53	68.23	55.25 %
1F 01.16 - 1F 01.16	44.74	29.17	67.77	56.96 %
1F 01.17 - 1F 01.17	62.76	25.81	56.42	54.25 %
1F 01.18 - 1F 01.18	64.27	30.51	61.99	50.78 %
1F 01.19 - 1F 01.19	43.29	31.30	72.73	56.96 %
2F 02.01 - 2F 02.01	44.58	29.32	70.86	58.62 %
2F 02.02 - 2F 02.02	69.49	25.25	56.41	55.24 %
2F 02.03 - 2F 02.03	49.10	28.10	66.37	57.66 %
2F 02.04 - 2F 02.04	69.49	25.18	56.35	55.31 %
2F 02.08 - 2F 02.08	71.75	24.74	55.84	55.69 %
2F 02.09 - 2F 02.09	48.45	28.29	67.47	58.07 %
2F 02.10 - 2F 02.10	50.23	27.95	65.95	57.62 %
3F 03.01 - 3F 03.01	44.58	30.07	71.43	57.90 %
3F 03.05 - 3F 03.05	52.99	54.42	90.79	40.06 %
3F 03.06 - 3F 03.06	50.88	42.67	82.41	48.22 %

Block Compliance

3F 03.07 - 3F 03.07	69.27	49.93	81.18	38.49 %
3F 03.08 - 3F 03.08	72.41	39.63	73.79	46.29 %
6F 06.04 - 6F 06.04	69.49	29.60	62.54	52.67 %
6F 06.05 - 6F 06.05	71.75	28.70	62.09	53.78 %
7F 07.01 - 7F 07.01	44.58	29.48	70.30	58.07 %
7F 07.02 - 7F 07.02	69.49	25.24	55.64	54.64 %
7F 07.04 - 7F 07.04	45.31	36.02	78.38	54.04 %
7F 07.05 - 7F 07.05	47.02	35.90	76.55	53.10 %
7F 07.06 - 7F 07.06	48.45	28.40	66.93	57.57 %
7F 07.07 - 7F 07.07	50.23	27.94	65.39	57.27 %
7F 07.08 - 7F 07.08	45.60	29.25	69.24	57.76 %
8F 08.01 - 8F 08.01	44.58	41.22	84.85	51.42 %
8F 08.02 - 8F 08.02	69.49	37.88	69.90	45.81 %
8F 08.03 - 8F 08.03	49.10	40.06	81.11	50.61 %
8F 08.04 - 8F 08.04	45.31	53.64	95.23	43.67 %
8F 08.05 - 8F 08.05	47.02	53.16	93.25	42.99 %
8F 08.06 - 8F 08.06	48.45	40.72	81.78	50.21 %
8F 08.07 - 8F 08.07	50.23	39.20	80.06	51.04 %
8F 08.08 - 8F 08.08	45.60	40.25	83.83	51.99 %
8F 08.16 - 8F 08.16	64.27	47.05	78.16	39.80 %
8F 08.17 - 8F 08.17	43.29	44.18	88.36	50.00 %
9F 09.01 - 9F 09.01	44.79	42.32	86.79	51.24 %
9F 09.02 - 9F 09.02	44.79	45.76	88.35	48.21 %
9F 09.03 - 9F 09.03	74.85	52.20	78.56	33.55 %
9F 09.04 - 9F 09.04	75.52	49.52	76.11	34.94 %
9F 09.05 - 9F 09.05	44.74	40.51	81.87	50.52 %
9F 09.06 - 9F 09.06	44.74	38.65	81.62	52.65 %
9F 09.07 - 9F 09.07	62.76	45.28	77.37	41.48 %

Block Compliance

2F 02.05 - 2F 02.05	106.52	28.35	53.75	47.26 %
2F 02.06 - 2F 02.06	69.27	29.69	63.45	53.21 %
2F 02.07 - 2F 02.07	72.41	25.12	57.18	56.07 %
2F 02.11 - 2F 02.11	45.60	29.06	69.84	58.39 %
4F 04.08 - 4F 04.08	45.60	29.02	69.84	58.45 %
5F 05.08 - 5F 05.08	45.60	29.03	69.84	58.43 %
6F 06.08 - 6F 06.08	45.60	29.06	69.84	58.39 %
2F 02.12 - 2F 02.12	44.79	29.24	71.55	59.13 %
3F 03.13 - 3F 03.13	44.79	30.13	71.55	57.89 %
4F 04.09 - 4F 04.09	44.79	29.28	71.55	59.08 %
5F 05.09 - 5F 05.09	44.79	29.41	71.55	58.90 %
6F 06.09 - 6F 06.09	44.79	29.33	71.55	59.01 %
7F 07.09 - 7F 07.09	44.79	29.62	71.55	58.60 %
8F 08.09 - 8F 08.09	44.79	29.77	71.55	58.39 %
2F 02.13 - 2F 02.13	44.79	30.13	73.12	58.79 %
3F 03.14 - 3F 03.14	44.79	31.94	73.12	56.32 %
4F 04.10 - 4F 04.10	44.79	30.14	73.12	58.78 %
5F 05.10 - 5F 05.10	44.79	30.26	73.12	58.62 %
6F 06.10 - 6F 06.10	44.79	30.28	73.12	58.59 %
7F 07.10 - 7F 07.10	44.79	30.54	73.12	58.23 %
8F 08.10 - 8F 08.10	44.79	31.08	73.12	57.49 %
5F 05.12 - 5F 05.12	75.52	31.16	60.20	48.24 %
2F 02.14 - 2F 02.14	74.85	33.03	63.95	48.35 %
4F 04.11 - 4F 04.11	74.85	33.67	63.95	47.35 %
5F 05.11 - 5F 05.11	74.85	35.51	63.95	44.47 %
6F 06.11 - 6F 06.11	74.85	35.14	63.95	45.05 %
7F 07.11 - 7F 07.11	74.85	35.89	63.95	43.88 %
8F 08.11 - 8F 08.11	74.85	36.13	63.95	43.50 %

Block Compliance



7F 07.12 - 7F 07.12	75.52	31.65	60.20	47.43 %
4F 04.12 - 4F 04.12	75.52	30.38	60.20	49.53 %
6F 06.12 - 6F 06.12	75.52	32.06	60.20	46.74 %
8F 08.12 - 8F 08.12	75.52	32.43	60.20	46.13 %
2F 02.16 - 2F 02.16	44.74	29.14	68.23	57.29 %
3F 03.17 - 3F 03.17	44.74	29.22	68.23	57.17 %
4F 04.13 - 4F 04.13	44.74	29.08	68.23	57.38 %
5F 05.13 - 5F 05.13	44.74	29.06	68.23	57.41 %
6F 06.13 - 6F 06.13	44.74	29.08	68.23	57.38 %
7F 07.13 - 7F 07.13	44.74	29.19	68.23	57.22 %
8F 08.13 - 8F 08.13	44.74	29.11	68.23	57.34 %
2F 02.17 - 2F 02.17	44.74	28.97	67.77	57.25 %
3F 03.18 - 3F 03.18	44.74	28.93	67.77	57.31 %
4F 04.14 - 4F 04.14	44.74	28.90	67.77	57.36 %
5F 05.14 - 5F 05.14	44.74	28.95	67.77	57.28 %
6F 06.14 - 6F 06.14	44.74	28.97	67.77	57.25 %
7F 07.14 - 7F 07.14	44.74	29.06	67.77	57.12 %
8F 08.14 - 8F 08.14	44.74	28.94	67.77	57.30 %
2F 02.18 - 2F 02.18	62.76	25.48	56.42	54.84 %
3F 03.19 - 3F 03.19	62.76	25.47	56.42	54.86 %
4F 04.15 - 4F 04.15	62.76	25.68	56.42	54.48 %
5F 05.15 - 5F 05.15	62.76	25.60	56.42	54.63 %
6F 06.15 - 6F 06.15	62.76	25.57	56.42	54.68 %
7F 07.15 - 7F 07.15	62.76	25.55	56.42	54.71 %
8F 08.15 - 8F 08.15	62.76	25.59	56.42	54.64 %
2F 02.19 - 2F 02.19	64.27	30.26	61.99	51.19 %
3F 03.20 - 3F 03.20	64.27	30.53	61.99	50.75 %
4F 04.16 - 4F 04.16	64.27	30.86	61.99	50.22 %

Block Compliance

5F 05.16 - 5F 05.16	64.27	30.69	61.99	50.49 %
6F 06.16 - 6F 06.16	64.27	30.92	61.99	50.12 %
7F 07.16 - 7F 07.16	64.27	31.39	61.99	49.36 %
2F 02.20 - 2F 02.20	43.29	30.12	72.73	58.59 %
3F 03.21 - 3F 03.21	43.29	30.76	72.73	57.71 %
4F 04.17 - 4F 04.17	43.29	30.00	72.73	58.75 %
5F 05.17 - 5F 05.17	43.29	29.99	72.73	58.77 %
6F 06.17 - 6F 06.17	43.29	30.01	72.73	58.74 %
7F 07.17 - 7F 07.17	43.29	30.92	72.73	57.49 %
3F 03.02 - 3F 03.02	69.49	25.30	56.01	54.83 %
3F 03.03 - 3F 03.03	49.10	28.75	67.47	57.39 %
3F 03.04 - 3F 03.04	69.49	25.46	55.95	54.50 %
5F 05.01 - 5F 05.01	44.58	29.67	71.43	58.46 %
5F 05.02 - 5F 05.02	69.49	25.44	56.01	54.58 %
5F 05.04 - 5F 05.04	69.49	25.46	55.95	54.50 %
5F 05.03 - 5F 05.03	49.10	28.75	67.47	57.39 %
3F 03.09 - 3F 03.09	71.75	24.57	55.82	55.98 %
5F 05.05 - 5F 05.05	71.75	25.04	55.82	55.14 %
3F 03.10 - 3F 03.10	48.45	29.07	68.04	57.28 %
5F 05.06 - 5F 05.06	48.45	28.82	68.04	57.64 %
3F 03.11 - 3F 03.11	50.23	28.25	65.91	57.14 %
5F 05.07 - 5F 05.07	50.23	28.06	65.91	57.43 %
4F 04.01 - 4F 04.01	44.58	29.45	70.86	58.44 %
6F 06.01 - 6F 06.01	44.58	29.43	70.86	58.47 %
4F 04.02 - 4F 04.02	69.49	25.07	56.41	55.56 %
6F 06.02 - 6F 06.02	69.49	25.43	56.41	54.92 %
4F 04.03 - 4F 04.03	49.10	27.95	66.37	57.89 %
6F 06.03 - 6F 06.03	49.10	28.27	66.37	57.41 %

Block Compliance

4F 04.04 - 4F 04.04	69.49	25.08	56.35	55.49 %
4F 04.05 - 4F 04.05	106.52	28.08	53.75	47.76 %
4F 04.06 - 4F 04.06	48.45	28.26	67.47	58.11 %
6F 06.06 - 6F 06.06	48.45	28.72	67.47	57.43 %
4F 04.07 - 4F 04.07	50.23	27.76	65.95	57.91 %
6F 06.07 - 6F 06.07	50.23	28.09	65.95	57.41 %
3F 03.12 - 3F 03.12	45.60	29.30	69.84	58.05 %
7F 07.03 - 7F 07.03	49.10	28.32	66.37	57.33 %
3F 03.15 - 3F 03.15	74.85	33.90	63.95	46.99 %
2F 02.15 - 2F 02.15	75.52	29.83	60.20	50.45 %
3F 03.16 - 3F 03.16	75.52	30.70	60.20	49.00 %
Totals:	9492.03	5216.81	11189.70	
Average DPER = 31.60 kWh/m ² /yr	% DPER/TPER	PASS		
Average TPER = 66.51 kWh/m ² /yr	52.49 %			