




TG20:21 compliance sheet

A tied independent tube and fitting scaffold in accordance with TG20:21 chapters 06 and 07.



Wind factor
20

Low

Maximum
height

10 metres

Maximum
boarded lifts

2

Maximum
lift height

2 metres

Maximum
bay length

2.4 metres

Maximum
boards wide

5 + 1

Maximum
loading

1.5 kN/m²

Tie load
Very light duty

1.8 kN

Maximum
leg load

9.6 kN

Sign-off

Contract no:
202506026

Client:
Hampshire Bee Company

Site reference:
12 Abbot's Walk, 12 Abbot's
Walk, Reading, Berkshire, RG1
3HW

Scaffold reference:
12 Abbots Walk

Company:
The Big Scaffolding Company Ltd

NASC membership no:

Not a NASC member

Caution, follow QR code for advice



Prepared by:
Jim Coleman

Position:
Managing Director

Signature:

Date:
19/06/2025

big scaffolding

Construction

- ✓ Constructed from type 4 galvanised steel tubes.
- ✓ Maximum 2 boarded lifts and 3 unboarded lifts permitted.
- ✓ Maximum transom spacing: 1.2 metres.
- ✓ Facade braced every 6 bays per elevation.
- ✓ Ledger braced at alternate standards and end frames.
- ✓ Double guard rails and toe boards at boarded lifts.
- ✓ Single guard rails at unboarded lifts.
- ✓ Internal edge protection may be provided where required.
- ✗ May not be clad with sheeting or debris netting.



Loading

- ✓ One lift loaded to 1.5 kN/m² (load class 2, light duty) plus one lift 50% loaded per facade.
- ✓ Maximum inside board loading 0.75 kN/m² at the working lift.
- ✓ Maximum leg load 9.6 kN, to be supplied to the client for foundation design.

Ties

- ✓ Tied at alternate lifts to TG20 tie pattern A with 1.8 kN (very light duty) ties.
- ✓ Tie tubes may be connected to the inner face of the scaffold. Additional sway resistance should be provided (TG20 section 7.9).
- ✗ The facade must not have significant openings.

Add-on features

- ✓ A gin wheel may be used to a maximum of 50 kg.
- ✗ No other add-on features are permitted without a TG20 compliance sheet or design advice.

Sign-off

Contract no:
202506026

Client:
Hampshire Bee Company

Site reference:
12 Abbot's Walk, 12 Abbot's
Walk, Reading, Berkshire, RG1
3HW

Scaffold reference:
12 Abbots Walk

Company:
The Big Scaffolding Company Ltd

NASC membership no:

Not a NASC member



Caution, follow QR code for advice

Prepared by:
Jim Coleman

Position:
Managing Director

Signature:

Date:
19/06/2025

Wind factor
20

LOW

Maximum
height

10 metres

Maximum
boarded lifts

2

Maximum
lift height

2 metres

Maximum
bay length

2.4 metres

Maximum
boards wide

5 + 1

Maximum
loading

1.5 kN/m²

Tie load
Very light duty

1.8 kN

Maximum
leg load

9.6 kN

big scaffolding